

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514718

Manufacturer: Asselin, Inc
2870 Peachtree Road Northwest, #714
Atlanta, GA 30305

Product Line: Series Fixed type F window, Non-Impact

Compliance:

The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 2051-2020-04 signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL 210-4186-3 signed by Christopher Bennet.
National Certified Testing Laboratories, Orlando, FL
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 35.0 psf
Water penetration resistance 5.25psf
3. Anchor calculations, report number 514718-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 35.0 psf
- Unit size: 59 1/16" x 82 11/16"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be French oak

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 2051-2020-04.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

