TURNER
ENGINEERING &
CONSULTING, INC.

2428 Old Natchez Trace Trail
Camden, TN 38320
Ph. 941-380-1574

Evaluation Report PEL-510B
October 7, 2026

Product Description: Series 515 PVC Picture Window, Large Missile Impact, Continuous Head and Sill, twin configuration with integral mullion, 74 1/8" x 72" unit size DP67.5

Manufacturer: Pella Corporation, 102 Main Street, Pella, IA 50219

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 9th Edition (2026) Florida Building Code including the HVHZ. The product testing standards performed are outlined below.

Technical Documentation:

1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
2) Approval drawing PEL-510B, signed and sealed by Lucas A. Turner, P.E.
3) Test Reports NCTL-210-3622-1, -1A, -2, -2A National Certified Testing Laboratories, Orlando, FL, signed and sealed by Gerard J. Ferrara, P.E. with testing performed with equivalency to: TAS 201/202/203-94, including impact at midspan of integral mullion, AAMA/WDMA/CSA 101/I.S.2/A440-11/17, ASTM E1886-13a/19, and ASTM E1996-17/20, including impact at midspan of integral mullion
4) Supplemental Calculations to support PEL-510B, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document PEL-510B.

Limitations of Use: This product:

- May be used in twin unit configuration O – integral mullion – O with continuous head and sill in sizes up to 74 1/8" x 72" unit size (36 3/8" max. single unit width), 75 3/8" x 73 1/4" flange size, with max. glass daylight sizes of 32 3/16" wide x 67 13/16" high
- Achieves a max. design pressure of +67.5/-67.5 psf
- Is large missile impact resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Requires 3/16Ann or Temp – Air – 1/8Ann-.105PVB-1/8Ann glass minimum
- Requires outer lite in I.G. to be safety glass when used in HVHZ above 30 ft of grade
- Requires Kuraray Butacite PVB Interlayer per current Miami-Dade NOA†
- Requires Quanex or Veka white rigid PVC framing per current Miami-Dade NOA†

† I have evaluated these interlayer and framing materials and find that they comply with the requirements of the 9th Ed. (2026) Florida Building Code for use in this product.

LUCAS A. TURNER
LICENSE
No. 58201
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Lucas Turner
2026.10.14
17:42:36 -05'00'

10/7/2026
Lucas A. Turner, P.E.
FL PE #58201

Coastal Compliance:

- Fastener criteria other than described below shall be in accordance with PEL-510B.
- Fasteners used in locations less than or equal to 300 ft from a saltwater coastline, where any portion of the fastener is located to the exterior of the Water-Resistive Barrier (WRB) of the wall construction, or is a Weather-Exposed Surface, or as otherwise required by the Authority Having Jurisdiction (AHJ), shall meet the criteria of FBC Sect. 1711.1.1.1 or RBC Section R332.1.1.1 as applicable.
    - For wood and metal installation substrates, requires stainless steel, 100 ksi min. ult. (cold worked).
    - For concrete/masonry substrates requires 1/4" Simpson Strong-Tie Type 316 Stainless-Steel Titen Turbo or 1/4" Dewalt Aggre-Gator 300 Series SS fasteners.
        - In solid concrete, 2.67 ksi min., requires 1-1/2" min. embedment and 1-1/2" min. edge distance.
        - In hollow or grout-filled CMU applications, ASTM C-90. requires 1-1/4" min. embedment and 2" min. edge distance.
- Fasteners used in locations less than or equal to 300 ft from a saltwater coastline, where the entire fastener is located to the interior of the WRB of the wall construction, or determined by the Registered Design Professional or AHJ for the project to be located within the Unconditioned Interior of the wall construction, or as otherwise required by the AHJ, shall meet the criteria of FBC Sect. 1711.1.1.2 or RBC Section R332.1.1.2 as applicable[††].
- Fasteners used in locations greater than 300 ft and up to 3000 ft from a saltwater coastline, in any Exterior/Interior location of the wall construction, or as otherwise required by the AHJ, shall meet the criteria of FBC Sect. 1711.1.1.2 or RBC Section R332.1.1.2 as applicable[††]

[††] ITW Tapcon and Dewalt Ultracon+ carbon steel fasteners as listed in Table 1 meet these criteria with coatings provided by the manufacturer. Kwik-Cote on Hilti Kwik-Flex and Climaseal on ITW TEKS fasteners also meet these corrosion resistance criteria. Other fasteners must be galvanized or otherwise coated in accordance with one of the standards provided in FBC Sect. 1711.1.1.2 or RBC Sect. R332.1.1.2.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Pella Corporation or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

10/7/2026
Lucas A. Turner, P.E.
FL PE #58201