

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
PERSPECTIVE GLASS COMPANY
750 SW 14 TH AVE.
POMPANO BEACH, FL

PRODUCT
SERIES PGC-2" PTAC
ALUMINUM LOUVER SYSTEM - LMI

UNIT 'A' TEST REPORT # D-9786.01-450-18
MAX. FRAME SIZE: 72" X 24"
DESIGN PRESSURE: (MAX.) = -90/+90 PSF

UNIT 'B' TEST REPORT # ATLSF 0821.01.20
MAX. FRAME SIZE: 84" X 24"
DESIGN PRESSURE: (MAX.) = -100/+100 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

SEE PRODUCT APPROVAL \DRAWINGS TO COORDINATE ALLOWABLE DESIGN PRESSURES FOR SPECIFIC UNIT SIZES,
ANCHOR LOCATION COMBINATIONS

MANITORY TESTS (TESTED IN ACCORDANCE WITH TAS 201/ TAS202 (STRUCTURAL ONLY)/TAS203)

UNIT A TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	TEST DATE	ENGINEER
ASTM E-330 & TAS 202	UNIFORM STATIC AIR PRESSURE	INTERTEK	D9786.01-450-18	7/21/14-7/22/14	VINU J. ABRAHAM

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

FBC 1626.2 TAS 201 & TAS 203	LARGE MISSILE IMPACT & CYCLIC	INTERTEK	D9786.01-450-18	7/21/14-7/22/14	VINU J. ABRAHAM
FBC 1626.3 TAS 201 & TAS 203	SMALL MISSILE IMPACT & CYCLIC	INTERTEK	D9786.01-450-18	7/21/14-7/22/14	VINU J. ABRAHAM

UNIT B TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	TEST DATE	ENGINEER
ASTM E-330 & TAS 202	UNIFORM STATIC AIR PRESSURE	ATL	ATLSF 0821.01-20	8/19/20	STEPHAN WARTER, PE

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

FBC 1626.2 TAS 201 & TAS 203	LARGE MISSILE IMPACT & CYCLIC	ATL	ATLSF 0821.01-20	8/19/20	STEPHAN WARTER, PE
FBC 1626.3 TAS 201 & TAS 203	SMALL MISSILE IMPACT & CYCLIC	ATL	ATLSF 0821.01-20	8/19/20	STEPHAN WARTER, PE


UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE LOUVER SYSTEM PRODUCT
CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2024.02.17
11:09:33 -05'00'

