



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

Detailed Product Description:**Manufacturer:** VIWINCO, INC.**Manufacturer Address:** PO BOX 499, MORGANTOWN, PA 19543**Model Name:** OCEANVIEW VINYL CASEMENT WINDOW**Maximum Load:** +70 PSF, -70 PSF (Large Missile Impact)**Installation Drawings #** 20-64F**FL 33810****Date:** 09/22/2026

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA 101/I.S.2/A440/NAFS)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Intertek B & C	9/22/2020	K2880.01-109-47	Daniel C. Culbert, P.E.
ASTM E331 & ASTM E547	Water Penetration	Intertek B & C	9/22/2020	K2880.01-109-47	Daniel C. Culbert, P.E.
ASTM E330	Uniform Static Air Press.	Intertek B & C	9/22/2020	K2880.01-109-47	Daniel C. Culbert, P.E.
ASTM F588	Forced Entry Test	Intertek B & C	9/22/2020	K2880.01-109-47	Daniel C. Culbert, P.E.

Supplemental Tests

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E1886/1996	Large Missile Impact & Cyclic	Intertek B & C	9/22/2020	K2880.02-109-47	Daniel C. Culbert, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq

PE # 81223

Al-Farooq Corporation

EB # 3538



Sealed: 9/22/2026