

# WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97<sup>th</sup> Road N  
West Palm Beach, FL 33412  
Ph/Fx: (561) 225-1982

## PRODUCT EVALUATION

PRODUCT: ARMOUR LOC 0.032" ALUMINUM 1 3/4" SNAPLOCK 18" WIDE  
ROOF PANEL – HVHZ (FLPA# 35255.5)

MANUFACTURER: 1<sup>ST</sup> COAST METAL ROOFING SUPPLY  
186 STATE ROAD 207  
EAST PALATKA, FL 32131

To all concerned,

The Armour Loc 0.032" Aluminum 1 3/4" Snaplock 18" Wide Roof Panel, manufactured by 1<sup>st</sup> Coast Metal Roofing Supply, is a non-structural Fluoropon painted aluminum roof panel (23 ksi min) that meets the requirements of Sections 1507.4 and 1518.9 of the 8<sup>th</sup> Edition (2023) Florida Building Code. The panel has been tested per TAS 100, TAS 125, and ASTM E8 by Intertek with results shown in test reports L1965.05-450-44-R1 and L1965.07-450-44-R1, and per TAS 110 by PRI Construction Materials Technologies, with results shown in test reports VLS-004-02-01 and VLS-005-02-01. I have reviewed the TAS 100 testing listed above and it is equivalent to TAS 100-23.

### Technical Documentation:

1. Drawing "1CASL18-HZ" dated 10/10/23, signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Architectural Testing, Inc. signed and sealed by Vinu Abraham, PE, and by PRI Construction Materials Technologies, signed and sealed by Zachary R Priest, PE.
3. Supplemental Calculations to support 1CASL18-HZ, signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code generally, and chapter 15 specifically, including the HVHZ provisions.

Limitations: This panel is approved for use inside and outside of the HVHZ.

<u>Overall Limitations:</u>	Maximum Panel Width:	18" (nominal)
	Minimum Rib Height:	1 3/4"
	Clip Anchors:	18 Ga. galvanized steel, 3 1/2" long
Min. Slope:	HVHZ:	2"/12"
	Non-HVHZ:	1/2"/12" (with Lap Sealant)
		3"/12" (no Lap Sealant)



Other Limitations:


1. Roof slope must meet requirements of FBC Sections 1507.4.2 or 1515.2.
2. Fire classification is not a part of this evaluation. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
3. Design of substrate is by others and is not a part of this evaluation.
4. All panel system perimeters, penetrations, and transitions to be flashed and sealed per the requirements of RAS 133.

Re-Roofing:

The Armour Loc 0.032" Aluminum 1 3/4" Snaplock x 18" Wide Roof Panel may be installed over a single layer of existing asphalt shingles, provided the existing roof meets all of the requirements of Section 1511 of the Florida Building Code.

If you have any questions or need more information concerning this approval, please contact me.

Thank you,

  
Scott Wolters  
FL PE# 62354  
OCT 10 2023

