



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 36855

Date: 10/17/2023

Detailed Product Description:

Manufacturer: DURAFLEX, a division of DURASERV Corp.

Manufacturer Address: 2951 Northern Cross Blvd., Suite 213, Fort Worth, TX 76137

Model Name: Series 'DuraFlex' (12'-2") Sectional Garage Door

Maximum Load: +46.7 PSF, -52.9 PSF (Non-Impact)

Installation Drawings # 20-31F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS-02/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E330 & TAS 202 ANSI/DASMA 108	Uniform Static Air Press.	Intertek B&C	03/09/2020	K2707.01-109-18 K2707.02-109-44 K2707.03-109-44	Daniel C. Culbert, P.E.
AAMA 1304	Forced Entry Test	Intertek B&C	03/09/2020	K2707.01-109-18	Daniel C. Culbert, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 10/17/2023