



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

**Stabilit America, Inc.
Resolite FS25A/CRFS25A '40' Series Roof Panel
(Non-HVHZ)**

for

Florida Product Approval

FL# FL37055

Report No. 9070

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Structural Components
Sub – Category:	Roof Deck
Product:	Resolite FS25A/CRFS25A '40' Series Roof Panel
Materials:	Fiberglass Reinforced Polyester Plastic Panel
Panel Weight:	10 oz/ft²
Product Dimensions:	See Installation Instructions STB001

Prepared for:

**Stabilit America, Inc.
285 Industrial Dr, Moscow
TN 38057**


Prepared by:

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 2/29/2024

Contents:

Evaluation Report Pages 1 – 4

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2024.02.29 15:11:52 -08'00'



Hermes F. Norero, P.E.
Florida P.E. No. 73778

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Manufacturer: Stabilit America, Inc.

Product Category: Structural Components

Product Sub-Category: Roof Deck

Compliance Method: State Product Approval Rule (1)(d)

Product Name: Resolite FS25A/CRFS25A '40' Series Roof Panel (Non-HVHZ)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Stabilit America, Inc.** based on **Method 1d** of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **STB001**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. Site conditions that deviate from the details of Installation Instructions **STB001** require further engineering analysis by a licensed engineer or registered architect.
4. See Installation Instructions **STB001** for size and design pressure limitations.
5. Installation Instructions **STB001** are in accordance with Current FBC section 1504.6, 1504.7, 2604.4, 2606.5, and 2612.
6. Product shall be installed with a minimum slope of ½:12.
7. Underlayment per manufacturer's guidelines according to Current FBC section 1507.1.1.
8. Roof design shall allow 1 sq ft for ventilation for every 150 sq ft of roof.
9. Panels shall be installed in accordance with FBC 2609 for CC1 class of plastics and the requirements of this evaluation.

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Quality Assurance: The manufacturer has demonstrated compliance of roofing products in Accordance with the Florida Building Code and State Rules for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Keystone Certifications, Inc.** (FBC Organization #: QUA 1824)

Performance Standards: The product described herein has been evaluated per:

- ASTM D1929-16
- ASTM D2843-16
- ASTM D635-14
- ASTM E1592-05(17)
- ASTM G154-16(a)
- FM 4470-16

Referenced Data:

1. Product Testing performed by **Force Engineering & Testing, Inc** (FBC Organization # TST5328)
Report #: 177-0082T-06A 08/18/2006
177-0082T-06B 08/18/2006
177-0082T-06C 08/18/2006
177-0082T-06D 08/18/2006
2. Product Testing performed by **PRI-Construction Materials Technologies, LLC** (FBC Organization # TST5878)
Report #: FAE-003-02-01 04/23/2012
FAE-004-02-01 04/23/2012
FAE-005-02-01 04/23/2012
3. Quality Assurance
Keystone Certifications, Inc.
(FBC Organization # QUA 1824)

Installation: Refer to Installation Instructions (**STB001**) for anchor types, spacing, and more details of the installation requirements.

Design Pressure: Refer to Installation Instructions (**STB001**) for design pressure configurations.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Sabilit America, Inc. has tested their products to the following test standard edition(s):

1. ASTM D1929-12
2. ASTM D2843-10
3. ASTM D635-10
4. ASTM G154-06
5. FM 4470-12

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

1. ASTM D1929-16
2. ASTM D2843-16
3. ASTM D635-14
4. ASTM G154-16a
5. FM 4470-16

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.