

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

Rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515233

Manufacturer: Nana Wall Systems, Inc.
100 Meadowcreek Drive, Suite 250
Corte Madera, CA 94925

Product line: HSW 60 System Non-Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03967, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: A3958.01-301-44 signed and sealed by Tyler Westerling P.E.
Architectural Testing, Fresno, CA
AAMA/WDMA/CSA 101/I.S.2/A440 Uniform Static Air Pressure: ± 45.0 psf design pressure
Water penetration resistance: 0.0 psf without weeps
6.06 psf with weeps
3. Anchor calculations and comparative, report number 515233-1 prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Unit size: Refer to approval drawing.
- Design pressure: Refer to approval drawing
- Units must be glazed per ASTM E1300 with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be aluminum.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

