

Product Evaluation Report**Report No.:** FL-38695.4**Date:** May 2, 2024

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Exterior Doors Components	Endura Products 8817 West Market Street Colfax, NC 27235 Phone: 336.665.4052	PanoLock Multi-Point Lock in a Single or Double Door Inswing / Outswing "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Endura Products, based on Rule Chapter No. 61G20-3, Method 1A of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product anchoring has been developed to be in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone". See the Certification Agency Certificate for sizes, specifications and ratings.
2. When used in the HVHZ, this product complies with FBC Section 1626 and does not require an impact resistant covering.
3. This product has been tested in the door panels as specified in this approval. Substitution into a similar product may be approved for use by the local Authority Having Jurisdiction. In all cases, the fiberglass single or double door system used must possess a comparable current Florida Statewide product approval (includes the HVHZ). The door panel size and design pressure (DP) rating shall not exceed the sizes and DP ratings shown in this approval or the side hinged swing single or double door approval being used.
4. Site conditions that deviate from the details of drawing FL-38695.4 require further engineering analysis by a licensed engineer or registered architect
5. See drawing FL-38695.4 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|--|---|--|
| 1. Test Report No.
TEL 3853326
TEL 3853327 | Test Standard
TAS 201, 202 & 203-94
TAS 201, 202 & 203-94 | Testing Laboratory
Testing Evaluation Lab.
Testing Evaluation Lab. | Signed by
William B. Shelton, P.E.
William B. Shelton, P.E. |
| 2. Drawing No.
No. FL-38695.4 | Prepared by
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |

Digitally signed by
Lyndon F Schmidt
Date: 2024.05.02
12:11:35 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 5-02-24.
Printed copies of this document are not considered signed and sealed and the
signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA