

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: 26 Ga. STAINLESS STEEL WALL TILES
(FLAT or CUPPED)

MANUFACTURER: MILLENNIUM FORMS
550 EAST CENTRALIA ST.
ELKHORN, WI 53121

To all concerned,

The 26 Ga. Stainless Steel Wall Tiles, manufactured by Millennium Forms, are flat or cupped face tiles formed from 26 Ga. 304 series Stainless Steel. The tiles have been tested per TAS 202 and TAS 203 by Intertek B&C, with results shown in test reports L5734.01-109-18 and L5740.01-109-18.

Technical Documentation:

1. Drawing "MF26SS-HZ" dated 10/11/24 (Rev. 1), signed and sealed by Scott Wolters, PE.
2. Test report listed above by Intertek B&C, signed and sealed by Daniel Culbert, PE.
3. Supplemental Calculations to support MF26SS-HZ, signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapters 14 and 16 specifically, including the HVHZ provisions.

Limitations: This Wall Tile System is approved for use inside and outside of the HVHZ. This system is not approved for impact resistance as a stand-alone product. In the HVHZ or windborne debris regions, it may only be installed over impact resistant substrates meeting the requirements of FBC Section 1626.

<u>Overall Dimensions:</u>	Maximum Tile Width:	14 5/8" (Nominal), 15.293" (overall)
	Maximum Tile Height:	8 1/4" (Nominal) 9.642" (overall)
	Maximum Design Pressure:	+/- 126 psf (Flat Tiles)
		+/- 116 psf (Cupped Tiles)

The system is further limited as noted in drawing "MF26SS-HZ"


If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters

FL PE# 62354

OCT 18 2024



SPECIALIZING IN MIAMI-DADE AND SOUTHERN FLORIDA, PRODUCT APPROVALS FOR ROOFING & GLAZING PRODUCTS