

Product Evaluation Report**Report No.: FL-40116.4****Date: August 8, 2023**

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	In & Out Products LLC 5032 Atkinson Road Orrum, NC 28369 954-612-3826	Glazed Fiberglass Entry Door w/ the Guard Dog Pet Door Inswing / Outswing "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for In & Out Products LLC, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code structural requirements excluding the "High Velocity Hurricane Zone".
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-40116.4 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-40116.4 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|---|--|
| 1. <u>Test Report No.</u>
TEL 06053714 | <u>Test Standard</u>
ASTM E 330-14, E 331-00 | <u>Testing Laboratory</u>
Testing Evaluation Lab., Inc. | <u>Signed by</u>
V.K. Wright |
| 2. <u>Drawing No.</u>
No. FL-40116.4 | <u>Prepared by</u>
RW Building Consultants, Inc. (#9813) | <u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E. | |
| 3. <u>Calculations</u>
Anchoring
ASTM E1300 Glass Load | <u>Prepared by</u>
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | <u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E. | |
| 4. <u>Quality Assurance</u>
Certificate of Participation issued by National Accreditation and Management Institute, certifying that In & Out Products LLC is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

Digitally signed by
Lyndon F Schmidt
Date: 2023.08.08
09:58:37 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-8-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA