



EVALUATION REPORT

FLORIDA BUILDING CODE 7TH EDITION (2020)

Manufacturer: Atlas Roofing Corporation
2000 Riveredge Parkway, Suite 800
Atlanta, GA 30328
(770) 612-6267
<http://www.atlasroofing.com>

Issued December 16, 2021

Manufacturing Plants: Perry, MO

Quality Assurance: Architectural Testing, Inc. (QUA1844)

SCOPE

Category: Roofing
Subcategory: Roofing Accessories that are an Integral Part of the Roofing System
Code Sections: 1503.5, 1709.2
Properties: Roof Ventilation

REFERENCES

<u>Entity</u>	<u>Report No.</u>	<u>Standard</u>	<u>Year</u>
PRI Construction Materials Technologies, Inc. (TST5878)	BOI-025-02-01	TAS 100(A)	1995

LIMITATIONS

- 1) This evaluation report is not for use in the HVHZ.
- 2) Fire Classification is outside the scope of this evaluation.
- 3) The roof deck and deck attachment shall be designed by others in accordance with the FBC.
- 4) Vents shall be installed in strict compliance with this evaluation report and the manufacturer's published installation instructions. In the event of conflict, this report shall hold precedence.
- 5) Deck substrates shall be clean, dry, and free from any irregularities and debris. All fasteners in the deck shall be checked for protrusion prior to installation.
- 6) Installation of the roof assembly is outside the scope of this evaluation.
- 7) Vents may be used as described in other current FBC product approval documents.
- 8) Vents are intended to provide passive ventilation for an enclosed attic in residential construction applications.
- 9) All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

PRODUCT DESCRIPTION AND APPLICATION

TruRidge Pro 25	TruRidge Pro 25 is a 14-11/16" wide by 5/8-inch thick, continuous, under-the-shingle ventilator made of injection-molded polypropylene.	
Deck Type:		Min. 15/32-inch APA span rated plywood sheathing (Designed by others in accordance with the FBC) for new and existing deck.
Roof slope:		3:12 – 16:12 (Not to exceed 12:12 for hip roofs)
Maximum Installation Height:		75 ft
Attachment method:		Galvanized or stainless steel roofing nails having min. 0.125-inch dia shank. and min.0.410-inch dia. head; Nails shall be of sufficient length to penetrate through the sheathing. Fasten vent 12-inches o.c. on either side of the ridge slot. Cap shingle secured through the vent and to the deck 5-inches o.c. on either side of the ridge slot.
Allowable roof coverings:		Asphalt shingles

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest, P.E. have demonstrated compliance with the Florida Building Code, 7th Edition (2020) as evidenced in the referenced documents submitted by the named manufacturer.



This item has been digitally signed and sealed by Zachary R. Priest, PE, on 12/16/2021.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Zachary R. Priest, P.E.
Florida Registration No. 74021
Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT