**PRODUCT APPROVAL EVALUATION REPORT**
RULE CHAPTER #61G20-3

**MANUFACTURER**
**CHAMPION PTAC, LLC**
4720 NW 15 TH AVE UNIT 4A
FORT LAUDERDALE, FL 33309

**PRODUCT**
**SERIES "NEVERLEAK" HURRICANE IMPACT PTAC LOUVER WITH**
**"NEVERLEAK" PTAC WALL SLEEVE ASSEMBLY**
ALUMINUM LOUVER SYSTEM - LMI

UNIT 'A'
MAX. FRAME SIZE: 42" X 16"
DESIGN PRESSURE: (MAX.) = -90/+90 PSF

TEST REPORT # ATLSF: 1110.01-21

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

SEE PRODUCT APPROVAL \DRAWINGS TO COORDINATE ALLOWABLE DESIGN PRESSURES FOR SPECIFIC UNIT SIZES, ANCHOR LOCATION COMBINATIONS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202 (STRUCTURAL ONLY)/TAS203)

**UNIT A**

| TEST | DESCRIPTION | TEST LOCATION | TEST REPORT # | REORT DATE | ENGINEER |
|---|---|---|---|---|---|
| ASTM E-330 & TAS 202 | UNIFORM STATIC AIR PRESSURE | ATL OF SOUTH FLORIDA | ATLSF: 1110.01-21 | 11/19/21 | STEPHEN WARTNER, P.E. #54395 |

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

| | | | | | |
|---|---|---|---|---|---|
| FBC 1626.5 AMCA 540 TAS 201 & TAS 203 | LARGE MISSILE - LEVEL "D" IMPACT & CYCLIC | ATL OF SOUTH FLORIDA | ATLSF: 1110.01-21 | 11/19/21 | STEPHEN WARTNER, P.E. #54395 |
| AMCA550-15 (REV. 09-18) | TEST METHOD FOR HIGH VELOCITY WIND DRIVEN RAIN RESISTANT LOUVERS | INTERTEK, WPB | N2946.01-450-44-R0 | | VINU ABRAHAM, P.E. |

**PLEASE NOTE: TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501**.

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

**EVALUATION REPORT ENGINEER**

**Christopher Stanton, P.E.**
Fla. P.E. #69316

**STANTON ENGINEERING INC.**
CERT. OF AUTHORIZATION
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431




This item has been digitally signed and sealed by Christopher Stanton, PE on 2/5/2022 using a SHA authentication code.

Printed Copies of this document are not considered signed & sealed and the SHA authentication code must be verified on any electronic copies.

Digitally signed by Christopher Stanton
Date: 2024.03.05 16:08:59 -05'00'