



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 40912

Date: 07/19/2023

Detailed Product Description:

Manufacturer: KPS Global, LLC

Manufacturer Address: 4201 North Beach Street, Ft Worth, TX 76137

Model Name: Walk-In Enclosures

Maximum Load: +60 PSF, -60 PSF (Large Missile Impact)

Installation Drawings # 22-02F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes and combination of span vs loads refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Tested in accordance with TAS-202, TAS-201 and TAS-203

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E330 & TAS 202	Uniform Static Air Press.	Architectural Testing	01/03/2007	64873.01-801-18 64893.01-801-18	Joseph A. Reed, PE
FBC 1626.2 TAS 201 & TAS 203	Large Missile Impact & Cyclic	Architectural Testing	01/03/2007	64873.01-801-18 64893.01-801-18	Joseph A. Reed, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 7/19/2023