

PRODUCT EVALUATION REPORT VISTA VIEW SLIDING GLASS DOOR LMI

Product: FL41125.1
Aldora Series Vista View Sliding Glass Door
Large Missile Impact Resistant.

Manufacturer: Aldora Aluminum & Glass Products, Inc.
4250 Coral Ridge Drive
Coral Springs, FL 33065
(954) 784-6900

Statement of Compliance:

This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 9N-3.005 (1), using 61G20-3.005 (1) Method 1 (d) (Engineering Evaluation). This product complies with the requirements of the Florida Building Code both inside and outside of the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) Installation Drawings **VVSGD2025-08-14**, Signed and Sealed by William D. Cook, P.E. on 01/09/2026.
- 2) Testing to TAS 201, TAS 202, and TAS 203 from Blackwater Testing Inc. 7341 Westport Pl. Suite 1A, West Palm Beach, FL 33413, Report No.:
 - **BT-ALD-21-004A** signed and sealed by Michael Caldwell P.E. 01/12/2022
 - **BT-ALD-21-004B** signed and sealed by Michael Caldwell P.E. 02/28/2022
 - **BT-ALD-22-001** signed and sealed by Michael Caldwell P.E. 06/09/2022
 - **BT-ALD-23-005** signed and sealed by Michael Caldwell P.E. 03/22/2024
 - **BT-ALD-23-002** signed and sealed by Michael Caldwell P.E. 06/05/2024
 - **BT-ALD-24-002** signed and sealed by Michael Caldwell P.E. 02/24/2025
- 3) Supplemental Calculations to support **VVSGD2025-08-14**, signed and sealed by William D. Cook, P.E.

Limitations of Use for this product:

- See Installation Drawings **VVSGD2025-08-14** for approved anchor methods and spacing.
- Product is impact rated and does not require the use of shutters in windborne debris regions.
- May be used inside and outside the High Velocity Hurricane Zone.
- See Installation Drawings **VVSGD2025-08-14** for size and design pressure limitations

Certification of Independence:

NV5 Inc. and William D. Cook, P.E., do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named in this evaluation report.


For further questions please contact this firm.

Sincerely,
NV5, INC.

William D. Cook, PE

William D. Cook PE, SECB
FL P.E. # 43904
FL S.I. # 2008

Digitally signed by
William D. Cook, P.E.
Contact Info:
Willy.Cook@NV5.com
Date: 2026.01.12
10:53:28-05'00'



William D. Cook, PE, State of Florida, Professional Engineer, License No. 43904

This document has been digitally signed and sealed by William D. Cook on the date indicated in the digital signature. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.