AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 41347
Date: 07/17/2026

Detailed Product Description:

Manufacturer: ALDORA ALUMINUM & GLASS PRODUCTS, INC.

Manufacturer Address: 4250 CORAL RIDGE DRIVE, SUITE 101, CORAL SPRINGS, FL 33065

Model Name: VISTA VIEW ALUMINUM FIXED CASEMENT WINDOW

Maximum Load: +80 PSF, -85 PSF (Large Missile Impact)

Installation Drawings # 22-34F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used _X_ Yes ___ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Blackwater Technical Services, Inc.	03/24/2022 09/09/2022	BT-ALD-21-007 BT-ALD-22-003	Michael Caldwell, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Blackwater Technical Services, Inc.	03/24/2022 09/09/2022	BT-ALD-21-007 BT-ALD-22-003	Michael Caldwell, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Technical Services, Inc.	03/24/2022 09/09/2022	BT-ALD-21-007 BT-ALD-22-003	Michael Caldwell, PE
ASTM F588	Forced Entry	Blackwater Technical Services, Inc.	03/24/2022 09/09/2022	BT-ALD-21-007 BT-ALD-22-003	Michael Caldwell, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 TAS 201 & 203 ANSI Z97.1	Large Missile Impact & Cyclic	Blackwater Technical Services, Inc.	03/24/2022 09/09/2022	BT-ALD-21-007 BT-ALD-22-003	Michael Caldwell, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ
LICENSE
No. 81223
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Sealed: 7/20/2026