

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

**PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D**

**FL 41396
Date: 8/11/2023**

Detailed Product Description:

Manufacturer: PEGASUS SOLAR INC.

Manufacturer Address: 506 WEST OHIO AVENUE, RICHMOND, CA 94804

Model Name: ROOF TOP PV MOUNTING SYSTEM – INTO OSB

Maximum Load: +75 PSF, -115 PSF


Installation Drawings # 23-37F

This product does <u>not</u> comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
Tested in accordance with TAS-202, TAS-100(A), ASTM D1761					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM D1761	Mechanical Fasteners in Wood	IAPMO IBT	08/04/2023	3349-23010	Barry A. Johnson, PE
TAS 100(A)	Wind Driven Rain Resistance	Intertek	07/31/2023	Q2311.01-109-18	Tanya A. Dolby, PE
TAS 202	Uniform Static Air Press.	Intertek	10/13/2022	P0121.01-303-18	Tyler Westerling, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538



Sealed: 8/11/2023