

Engineering Evaluation Report - #4300-02062026-01

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: 29296

Manufacturer:

MI Windows and Doors
650 West Market Street
Gratz, PA 17030
(717) 365-3300

Product Description:

Series 4300 SP Vinyl Picture Window – Large Missile Impact Resistant – FL 41600

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number 4300 SP PW-FPA-LM, signed and sealed by A. Lynn Miller, P.E.

Anchor Calculations signed and sealed by A. Lynn Miller, P.E., dated 02/03/26.

Test Reports:

Report No.: 1413.03-106-12-R0 Molimo LLC., York, PA, Signed by Michael D. Stremmel, P.E.

Report No.: F6071.02-109-47 Intertek-ATI, York, PA, Signed by Timothy J. McGill

AAMA 506-11

ASTM E1886-13a

ASTM E1996-14a

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is NOT rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind born debris regions up to wind zone 3.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.

Certification of Independence:

A. Lynn Miller, P.E., is employed by MITER Brands and therefore has a financial interest in the company or any company manufacturing or distributing products for which this report is being issued, but does not, nor will acquire a financial interest in any other entity involved in the approval process of this product.

