



# AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 41748

Date: 10/06/2026

### Detailed Product Description:

**Manufacturer:** OIKOS VENEZIA SRL

**Manufacturer Address:** Via Della Tecnica 6, 30020 Gruaro, Venezia, Italy

**Model Name:** Series Synua-12 Outswing Pivot Door

**Maximum Load:** +65 PSF, -65PSF (Large Missile Impact)

**Installation Drawings #** 22-39F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

### Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

| TEST                | DESCRIPTION               | TEST LOCATION          | TEST REPORT DATE | TEST REPORT # | Test Sealed by      |
|---------------------|---------------------------|------------------------|------------------|---------------|---------------------|
| ASTM E283           | Air Infiltration Leakage  | Blackwater Testing Lab | 03/10/2022       | BW-OIK-22-001 | Roberto Archila, PE |
| ASTM E330 & TAS 202 | Uniform Static Air Press. | Blackwater Testing Lab | 03/10/2022       | BW-OIK-22-001 | Roberto Archila, PE |
| AAMA 1304           | Forced Entry Test         | Blackwater Testing Lab | 03/10/2022       | BW-OIK-22-001 | Roberto Archila, PE |

### Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)


| TEST                     | DESCRIPTION                   | TEST LOCATION          | TEST REPORT DATE | TEST REPORT # | TEST SEALED BY      |
|--------------------------|-------------------------------|------------------------|------------------|---------------|---------------------|
| FBC 1626.2 TAS 201 & 203 | Large Missile Impact & Cyclic | Blackwater Testing Lab | 03/10/2022       | BW-OIK-22-001 | Roberto Archila, PE |

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

### Evaluation Report Engineer:

Jalal Farooq  
Al-Farooq Corporation

PE # 81223  
EB # 3538



Sealed: 10/12/2026