



Project Number: U2716-0374-231
September 7, 2023

Product Approval Administrator
Building Codes & Standards Section
Department of Business & Professional Regulations
1940 North Monroe Street, Suite 90
Tallahassee, FL 32399-2100

REFERENCE: **Florida Product Approval of SMR Roof Mount Systems – 2023 FBC
Product Approval Evaluation – Chapter #61G20-3**

Manufacturer: SunModo Corp
Manufacturer Address: 14800 NE 65th Street, Vancouver, WA 98682
Model Name: SMR Flush Mount PV Racking System
Maximum Design Load: +/- 117.8 psf (Non-Impact)


Testing Summary					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
TAS 202	Uniform Static Air Pressure	Intertek	08/30/2022	N9714.01-109-18	Tanya A Dolby, P.E.
This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements					
For maximum sizes, spans, loads and anchor types, refer to the installation drawings.					
This product is UL listed in accordance with UL2703 per Intertek report # 104049973LAX-001					
To the best of my knowledge, the above product conforms to the requirements of the 2023 Florida Building Code when installed in accordance with the instructions and limitations outlined in the attached installation drawings.					

Sincerely,
VECTOR STRUCTURAL ENGINEERING, LLC

Russell N Emery
2023.09.14
14:46:18-06'00'

Russell Emery, P.E.
License #: 71060, Expires 02/28/2025
Project Engineer

RNE/mih
Enclosures



09/14/2023

Russell N. Emery
No. 71060

This item has been digitally signed and sealed by Russell N. Emery on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.