

**L. Roberto Lomas P.E.**

208 7<sup>th</sup> Avenue

Indialantic, FL 32903

434-688-0609

rlomas@rlomaspe.com

## Engineering Evaluation Report

**Report No.: 514651B**

**Manufacturer:**           **MI Windows & Doors, LLC.**  
**650 West Market Street**  
**Gratz, PA 17030-0370**

**Product Line:**   Series 3540 Finless PVC Single Hung Steel Reinforced Non-Impact

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03569 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: G0970-109-47 signed by Timothy J. McGill  
Architectural Testing, Inc. York, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:                   ±30.08psf  
Water penetration resistance:   4.59psf
3. Anchor calculations, report number 514651-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: ±30.0psf
- Unit size:               48" X 84"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame and sash material: Extruded PVC.
- Sash and fixed meeting rail reinforcement: Roll formed steel.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03569, Revision B.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

