

## EVALUATION REPORT

---

|                      |                                                                     |                           |                                                |
|----------------------|---------------------------------------------------------------------|---------------------------|------------------------------------------------|
| <b>Title:</b>        | Aluminum Window Wall                                                |                           |                                                |
| <b>Report #:</b>     | SM2023-010R1                                                        |                           |                                                |
| <b>Manufacturer:</b> | Sun Metals Systems, Inc.<br>5008 Tampa West Blvd<br>Tampa, FL 33634 | <b>Technical Contact:</b> | Eric VanHorn, P.E.<br>VanHorn Engineering, LLC |
| <b>Prepared by:</b>  | Gordon Thomas, P.E.<br>Florida # 46718                              | <b>Date:</b>              | April 6, 2023<br>July 26, 2025 - revised       |

---

### I. OVERVIEW / SCOPE

The following evaluation report provides a review of a revised FBC application for a Window Wall. The current configurations are listed under FL 41967 and this evaluation will review the requirements to receive approval for the 8<sup>th</sup> Edition (2023) FBC.

### II. REFERENCE MATERIAL

The following reference materials were provided in support of the product evaluation:

1. Florida Product Approval FL 41967, 2020 Florida Building Code
2. Sun Metals Dwg FL-41967.4. Dated 7/14/25. 7 Sheets.
3. Testing Evaluation Laboratories, 2002 Wood Court Suite 1, Plant City, FL 33563  
Report TEL 01500115, Dated May 1, 2009, Signed and Sealed by Lyndon F. Schmidt, P.E.
4. Intertek, 2658 Electronics Way, West Palm Beach, FL 33407  
Test Report # M3921.01-450-18-r0. Dated 12/6/22, Signed and Sealed by Vinu Abraham, P.E.

### III. EVALUATION CRITERIA & LIMITATIONS OF USE

The product has been evaluated and is in compliance with the 8<sup>th</sup> Edition (2023) Florida Building Code structural requirements including the "High Velocity Hurricane Zone". The drawings cited below and as illustrated in Appendix A of the test report are an explicit part of this evaluation report. The text of this report cannot address all design details (fastener size, spacing) but relies upon the illustrations of these drawings. All testing frame specimens listed in test reports referenced above were conducted as follows:

TAS 201-94 (Impact Test Procedures)

TAS 202-94 (Uniform Static Air Pressure)


TAS 203-94 (Criteria for Testing Products Subject to Cyclic Wind Pressure Loading)

Product listed meets the deflection recovery requirements.

Product listed meets small missile impact ratings.


Product listed meets static pressure air infiltration.

In Section 1709.8.4 of the Florida Building Code, it states "that window wall and storefront systems shall be tested in accordance with the requirements of this section and the laboratory test requirements of the American Architectural Manufacturers Association (AAMA) Standard 501, HVHZ shall comply with Section 2411.3.2.1.1". It has been determined that the results and tests conducted as listed in the test reports above meet the requirements for compliance with AAMA 501-05.



The following products were reviewed and approved:

| Product Name | Product Type               | Max DLO Size     | Design Pressures | Impact Rating                      | Dwg        |
|--------------|----------------------------|------------------|------------------|------------------------------------|------------|
| Series 650T  | Aluminum Fixed Window Wall | 43.38" x 90.81"  | +/- 100 PSF      | Small Missile G1 - 1-5/16" Glazing | FL-41967.4 |
| Series 650T  | Aluminum Fixed Window Wall | 43.38" x 114.69" | +/- 100 PSF      | Small Missile G2 - 1-5/16" Glazing | FL-41967.4 |



---

Certification of Independence of Evaluation Entity

I hereby certify that (1) I have no financial interest in Sun Metals Systems, LLC; (2) I am an independent licensed Professional Engineer in the State of Florida and; (3) I comply with the criteria of independence as stated in 9B-72.110 (3), F.A.C. and 9B-72.110(4), F.A.C.