

WALTER A. TILLIT, JR., P.E.

tilteco@aol.com
FL P.E. License No. 44167
FL C.A. License No. 0006719

PRODUCT EVALUATION REPORT

REPORT NO.: 23-0825.01

DATE: August 25, 2023

PRODUCT CATEGORY: Impact Protective Systems

PRODUCT SUB-CATEGORY: Operable

PRODUCT NAME: **IMPACT PROTECTIVE ROLLING SYSTEM
WITH GV-60 END RETENTION SLAT**


SUBMITTED BY: **GAVIOTA**
Cerrada de Acolotenco 237, Bodega 48
Colonia San Sebastian, P.I. Pical Pantaco
Ciudad de Mexico 02510

1. PURPOSE OF EVALUATION:

This is a Product Evaluation Report issued by **Walter A. Tillit, Jr., P.E.** (System ID # 1906) to **GAVIOTA**, based on **Rule Chapter No. 61G20-3, Method 1D of the Florida Department of Business and Professional Regulation.**

This product is being issued an Evaluation Report as described herein, and has been verified for compliance in accordance with the 2023 8th Edition of the Florida Building Code, and to verify that the product is for the purpose intended, at least equivalent to that required by the Code.

This Product Evaluation Report shall be subject to review and revision in case of a Building Code Change that may affect its limitations and conditions.



2. EVIDENCE SUBMITTED:

2.1. PRODUCT EVALUATION DOCUMENT (P.E.D.):

Drawing No. 23-190, titled **"IMPACT PROTECTIVE ROLLING SYSTEM"**, sheets 1 thru 22 of 22, prepared by Tilteco, Inc.; signed and sealed by Walter A. Tillit, Jr., P.E.; dated 08/25/2022. This drawing is an integral part of this Evaluation Report.

2.2. TEST REPORTS:

Large missile impact and cyclic loading under TAS 201 & TAS 203 Protocols, as per section 1626 of the Florida Building Code. Uniform Static loads in accordance with Protocol TAS 202 of the Florida Building Code. Test reports prepared by Blackwater Testing Inc. Report No. BT-GIO-22-001, signed and sealed by Michael Caldwell, P.E.

2.3. STRUCTURAL ENGINEERING CALCULATIONS:

On **"Impact Protective Rolling System with GV-60 End Retention Slat"** for Maximum span vs. design wind load, as well as anchor spacing vs. design wind load and Abatement span including mullions, based on rational and comparative analysis, and in accordance with sections 1616 and 2003 of the Florida Building Code. Calculations prepared by Tilteco, Inc., dated 08/05/2022, signed and sealed by Walter A. Tillit, Jr., P.E.

3. MISSILE IMPACT RESISTANCE:


Large missile impact under section 1626 of the Florida Building Code, as per TAS 201 Protocol (Large Missile), 50Ft/Sec, 9Lb 2" X 4".

4. WIND LOADS RESISTANCE:

"Impact Protective Rolling System with GV-60 End Retention Slat" has been verified to sustain wind pressures. Slat Span shall be as indicated on sheets 13 and 17 of Product Evaluation Document (P.E.D.), drawing No. **23-190**. Maximum Anchor Spacing shall be as indicated on sheets 14, 15, & 18 of Product Evaluation Document (P.E.D.), drawing No. **23-190**. Mullion span shall be as indicated on sheets 19 thru 21 of Product Evaluation Document (P.E.D.), drawing # **23-190**.

5. INSTALLATION:

Shall be strictly performed in accordance with the details indicated on sheets 4, 5, 6, 7, 8, 9, 10, and 11 of Product Evaluation Document (P.E.D.), drawing No. **23-190**. Minimum separation to glass shall be as indicated on sheets 13 and 17 of Product Evaluation Document (P.E.D.), drawing No. **23-190**



6. MATERIAL CHARACTERISTICS AND SPECIFICATIONS:

Shall be strictly in accordance with General Notes and Components indicated on sheets 1, 2 and 3 of Product Evaluation Document (P.E.D.), drawing No. **23-190**. Anchor specifications shall be as indicated on sheets 1, 7, 8, 9, 10, 11 of Product Evaluation Document (P.E.D.), drawing No. **23-190**.

7. LIMITATIONS AND CONDITIONS OF USE:

7.1. Shall be strictly in compliance with General Notes No.1, 2 and 10 thru 15 , indicated on sheet 1, as well as details and notes on sheet 17 of Product Evaluation Document (P.E.D.), drawing No. **23-190** prepared by Tilteco, Inc. and signed and sealed by Walter A. Tillit, Jr., P.E.

7.2. Product **may** be installed within HIGH VELOCITY HURRICANE ZONES as defined on section 202 of the Florida Building Code.

7.3. Product shall only be installed into poured concrete, grouted cell concrete block, and wood frame structures, as limited and defined on Product Evaluation Document No. **23-190**.

Product Evaluation Report prepared by Walter A. Tillit, Jr., P.E. (Florida License No. 44167), President of Tilteco, Inc. (Florida CA-0006719).

WAT\MA

D:\TILTECO ADMN RECORDS \ P. EVALUATION REPORT.23 \ GAVIOTA \ IMPACT PROTECTIVE ROLLING SYSTEM
\ DRWG # 23-190 \ REPORT #23-0825.01

