

Engineering Evaluation Report - #9300-08182026

Prepared by:

A. Lynn Miller, P.E.
3400 Precision Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

MI Windows and Doors
650 West Market Street
Gratz, PA 17030
(717) 365-3300

Product Description:

Series M-9310 & M-9316 Aluminum Structural Mullions – Large Missile Impact Resistant – FL 42087

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number M9310M9316-LM, signed and sealed by A. Lynn Miller, P.E.

Mullion Analysis, prepared, signed and sealed by A. Lynn Miller, P.E., dated 12/8/24.

Test Reports:

11398.04-106-12-R1, signed and sealed by Michael D. Stremmel, P.E.,
Molimo Architectural Product Testing, York, Pennsylvania 17402
AAMA 450-10, Option #1
AAMA/WDMA/CSA 101/I.S.2/A440-17

Limitations and Conditions of use:

- This product is impact resistant and does not require impact protection in wind borne debris regions, up to wind zone 3.
- Mullion material to be 6005-T5 or 6105-T5 Aluminum. Clip material to be 16 Ga. (0.063") Galvanized Steel.
- Units attached to mullion must have their own separate approval.
- Units must be installed in accordance with Approval Documents.

