

PRODUCT APPROVAL EVALUATION REPORT

Product Manufacturer: Cuhadaroglu Metal San. Paz. A.S. <i>Yakuplu Mah. Hurriyet Bulvari No:6-8 Beylikduzu Istanbul, Turkiye 34524</i>	Product Name/Model & Description: Series TH-HS-33 aluminum sliding window – L.M.I. & S.M.I.
---	--

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 8th Edition Florida Building Code (2023)/ 9th Edition Florida Building Code (2026), inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer


Product Description: Product Approval Drawing #AD23-09 and #AD23-19, prepared by MCY Engineering, signed and sealed by the Yiping Wang P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside of the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Large and Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Other load limitations applicable to the product, if any.
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to the structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.




Sep.20th, 2026



Test Reports:

Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-21-001</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (large and small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (water infiltration) ASTM F588 (forced entry)
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-21-002</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (small missile impact test) TAS 203 (cyclic wind pressure loading)
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-22-001</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (large and small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (water infiltration) ASTM F588 (forced entry)
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-22-002</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (large and small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (water infiltration) ASTM F588 (forced entry)
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-22-003</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (large and small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (water infiltration) ASTM F588 (forced entry) AAMA 1304 (forced entry)
Black water testing lab, Miami Dade Certification 18-0920.03	<i>BW-CUH-23-001</i> <i>signed and sealed</i> <i>by ROBERTO</i> <i>ARCHILA, P.E.</i>	09/16/2022	TAS 201 (large and small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (water infiltration) ASTM F588 (forced entry)



MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 MIRAMAR PARKWAY #301
Miami, FL. 33027
P: 305 588-5224

Engineering Analysis: The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- Rational analysis has been performed per Code requirements and acceptable standards of engineering principles (but not in lieu of standard tests required by the Code). No increase in allowable stress has been used in the evaluation of this product.