



WALTER A. TILLIT, JR., P.E.

tilteco@aol.com
FL P.E. License No. 44167
FL C.A. License No. 0006719

PRODUCT EVALUATION REPORT

REPORT No.: 26-0811.02

DATE: August 11, 2026

PRODUCT CATEGORY: Exterior Doors

PRODUCT SUB-CATEGORY: Swinging Exterior Door Assemblies

PRODUCT NAME: AB-2301 ALUMINUM OUTSWING FRENCH DOOR
(L.M.I)


MANUFACTURER: AMERICA'S BEST WINDOW & DOOR, LC
1350 PARK CENTRAL BLVD. SOUTH
POMPANO BEACH, FL 33064

1. PURPOSE OF EVALUATION:

This is a Product Evaluation Report issued by **Walter A. Tillit, Jr., P.E.** (System ID # 1906) to **America's Best Windows & Doors** based on **Rule Chapter No. 61G20-3, Method 1D** of the **Florida Department of Business and Professional Regulation**.

This product is being issued an Evaluation Report as described herein and has been verified for compliance in accordance with the 2026 9th Edition of the Florida Building Code, and to verify that the product is for the purpose intended at least equivalent to that required by the Code.

This Product Evaluation Report shall be subject to review and revision in case of a Building Code change that may affect its limitations and conditions.



2. EVIDENCE SUBMITTED:

2.1. PRODUCT EVALUATION DOCUMENT (P.E.D.):

Drawing No. 26-260, titled "AB-2301 ALUMINUM OUTSWING FRENCH DOOR (L.M.I)" sheets 1 thru 10 prepared by Tilteco, Inc.; signed and sealed by Walter A. Tillit, Jr., P.E.; dated 8/11/2026. This drawing is an integral part of this Evaluation Report.

2.2. TEST REPORTS:

Impact and Cyclic Tests as per protocol TAS-201, TAS-203, Uniform Static Load as per Protocol TAS 202 per sections 1626 and 1609.1.2, respectively of the Florida Building Code.

Test reports prepared by American Test Lab of South Florida, Report No. 0526.01-23, dated 6/17/2023 signed and sealed by Stephan W. Warter P.E.

2.3. STRUCTURAL ENGINEERING CALCULATIONS:

On "AB-2301 ALUMINUM OUTSWING FRENCH DOOR (L.M.I)" for Maximum Pressure Rating vs. Maximum anchor spacing, maximum width and height and Maximum Glass Size, based on rational and comparative analysis, in accordance with sections 1604 and 1616 of the Florida Building Code. Calculations Prepared by Tilteco, Inc., dated 6/22/2023, signed and sealed by Walter A. Tillit, Jr., P.E. Glass verified per ASTM E-1300-16, per section 2404.1 of the Florida Building code.


3. MISSILE IMPACT RESISTANCE:

Large Missile Impact resistance is provided per TAS 201 (9 lbs., 50 feet/sec, 2" x 4" Large Missile).

4. WIND LOADS RESISTANCE:

On "AB-2301 ALUMINUM OUTSWING FRENCH DOOR (L.M.I)" has been verified to keep sustain wind pressures. Maximum Glass Panel Dimensions, Panel Width, & Panel Height shall be as indicated on sheet 5 of Product Evaluation Document (P.E.D), Drawing No. 26-260.

Maximum Design Pressure Rating for Stiles Top and Bottom connections with Fasteners Clusters and anchors at jambs for applicable substrates shall be as indicated on sheet 5, of Product Evaluation Document (P.E.D), Drawing No.26-260.



5. INSTALLATION:

Installation shall be performed strictly in accordance with General Notes # 1 thru 7 and 9 thru 11, indicated on sheet 1 and details indicated on sheets 4 thru 10 of Product Evaluation Document (P.E.D.), drawing No. **26-260**.

Gaskets and setting blocks used at installations comply with section 2411.3.4 of the Florida Building Code as specified on Bill of Materials on Sheet 2 of Product Evaluation Document (P.E.D.), drawing No. **26-260**.

6. MATERIAL CHARACTERISTICS AND SPECIFICATIONS:

Shall be strictly in accordance with General Notes and Components indicated on sheets 2 and 3 of Product Evaluation Document (P.E.D.), Drawing No. **26-260**.

Anchor specifications shall be as indicated on Note 8, sheet 1 of Product Evaluation Document (P.E.D.), Drawing No. **26-260**.

7. LIMITATIONS AND CONDITIONS OF USE:

7.1. Shall be strictly in compliance with General Notes No. 1 thru 5, indicated on sheet 1 of Product Evaluation Document (P.E.D.), Drawing No. **26-260** prepared by Tilteco, Inc. and signed and sealed by Walter A. Tillit, Jr., P.E.

7.2. Product **may** be installed within HIGH VELOCITY HURRICANE ZONES as defined on section 202 of the Florida Building Code and out of it.

7.3. Product shall only be installed into substrates with limitations as indicated on sheets 5 and General Note 8, sheet 1 of Product Evaluation Document (P.E.D.), Drawing No. **26-260**.

Product Evaluation Report prepared by Walter A. Tillit, Jr., P.E. (Florida License No. 44167), President of Tilteco, Inc. (Florida CA-0006719).

WAT\ma

D:\TILTECO ADMIN RECORDS \ P. E. REPORT.26 \ AMERICA'S BEST WINDOW & DOOR, LLC \ AB-2301 ALUMINUM OUTSWING FRENCH DOOR (L.M.I) \ DRWG # 26-260 \ REPORT # 26-0811.02.

