

Evaluation Report FPA-Supera-Comp-NI
January 24, 2024

Product Description: Supera Composite Fixed Window with Integral Mullions

Manufacturer: Intus Windows, 2720 Prosperity Ave., Suite 400-1, Fairfax, VA 22031

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th (2023) Edition of the Florida Building Code outside the HVHZ. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FPA-Supera-Comp-NI, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports 12200.01/02/03/04/05/06, from Molimo, York, PA, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-17
- 4) Supplemental Calculations to support FPA-Supera-Comp-NI, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-Supera-Comp-NI.

Limitations of Use: This product:

- May be used in the sizes and Design Pressures as shown in FPA-Supera-Comp-NI
- Is non-impact and requires glazing as shown in FPA-Supera-Comp-NI.
- May not be used in the High Velocity Hurricane Zone
- Requires Gealan white rigid PVC framing with current AAMA/FGIA 303 Profile Certification

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Intus Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2024.03.06
13:35:00 -06'00'

1/24/2024
Lucas A. Turner, P.E.
FL PE #58201