

Evaluation Report FPA-8200PLUS-PW

November 9, 2023

Product Description: 8200 Plus Picture Window

Manufacturer: Great Day Improvements, 700 Highland Rd., Macedonia, OH 44056

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) of the Florida Building Code for use outside the HVHZ. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FPA-8200PLUS-PW, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Report P8302.01-501-47-r1, from Intertek, Springdale, PA, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-17
- 4) Supplemental Calculations to support FPA-8200PLUS-PW, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-8200PLUS-PW.

Limitations of Use: This product:

- May be used in the sizes and Design Pressures as shown in FPA-8200PLUS-PW
- Requires min. glazing as shown in FPA-8200PLUS-PW.
- Is not impact resistant, and requires impact protective devices (shutters) in windborne debris regions.
- May not be used in the High Velocity Hurricane Zone.
- Requires Deceuninck rigid PVC framing with current AAMA/FGIA 303 Profile Certification

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Great Day Improvements or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2023.11.27
11:49:22 -06'00'

11/9/2023
Lucas A. Turner, P.E.
FL PE #58201