



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 46082

Date: 12/28/2023

Detailed Product Description:

Manufacturer: PEGASUS SOLAR INC.

Manufacturer Address: 506 WEST OHIO AVENUE, RICHMOND, CA 94804

Model Name: ROOF TOP PV MOUNTING SYSTEM WITH SKIPRAIL CLAMP

Maximum Load: +36.7 PSF, -55.0 PSF

Installation Drawings # 23-64F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
Tested in accordance with TAS-202, TAS-100(A), ASTM D1761					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM D1761	Mechanical Fasteners in Wood	IAPMO IBT	10/17/2022 01/28/2023 07/17/2023	3349-22001 3349-23006 3349-23009	Woods McRoy, PE Barry A. Johnson, PE Barry A. Johnson, PE
TAS 100(A)	Wind Driven Rain Resistance	Intertek	09/28/2022 09/28/2022 09/28/2022 01/17/2023 08/04/2023	N9695.01-109-18 N9697.01-109-18 P2193.01-109-18 P5893.01-109-18 Q3155.01-109-18	Tanya A. Dolby, PE
TAS 202	Uniform Static Air Press.	Intertek	10/13/2022 11/30/2023	P0121.01-303-18 Q3573.01-109-18	Tyler Westerling, PE Tanya A. Dolby, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538



Sealed 12-28-2023