

Product Evaluation Report**Report No.: FL-46121.5****Date: February 5, 2025**

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	ODL, Inc. 215 East Roosevelt Avenue Zeeland, MI 49464 Phone 616.748-5437	Flush Glazed Fiberglass Door Double w/ or w/out Sidelites Inswing/Outswing "Non-Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. for ODL, Inc. based on Rule Chapter No. 61G20-3, Method 1d of the State of Florida Product Approval, Florida Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of this drawing require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-46121.5 for size and design pressure limitations.

Supporting Documents:

- | | | | | | | | | | | | | |
|--|---|--|---|--|--|---|--|---|--|--|--|--|
| <ol style="list-style-type: none"> 1. Test Report No.
TEL 01313865
TEL 01313855B
TEL 01313846A 2. Drawing No.
No. FL-46121.5 3. Calculations
Anchoring
ASTM E 1300 Glass Load 4. Quality Assurance
Certificate of Participation issued by Keystone Certifications, Inc., certifying that ODL is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | <table border="0"> <tr> <td style="vertical-align: top;"> Test Standard
ASTM E330-14/E331-00
ASTM E330-14/E331-00
ASTM E330-14/E331-00 </td> <td style="vertical-align: top;"> Prepared by
RW Building Consultants, Inc. (#9813) </td> </tr> <tr> <td style="vertical-align: top;"> Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) </td> <td></td> </tr> </table> | Test Standard
ASTM E330-14/E331-00
ASTM E330-14/E331-00
ASTM E330-14/E331-00 | Prepared by
RW Building Consultants, Inc. (#9813) | Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | | <table border="0"> <tr> <td style="vertical-align: top;"> Testing Laboratory
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright </td> <td style="vertical-align: top;"> Signed by
V.K. Wright
V.K. Wright
V.K. Wright </td> </tr> <tr> <td></td> <td style="vertical-align: top;"> Signed & Sealed by
Lyndon F. Schmidt, P.E. </td> </tr> <tr> <td></td> <td style="vertical-align: top;"> Signed & Sealed by
Lyndon F. Schmidt, P.E. </td> </tr> </table> | Testing Laboratory
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright | Signed by
V.K. Wright
V.K. Wright
V.K. Wright | | Signed & Sealed by
Lyndon F. Schmidt, P.E. | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| Test Standard
ASTM E330-14/E331-00
ASTM E330-14/E331-00
ASTM E330-14/E331-00 | Prepared by
RW Building Consultants, Inc. (#9813) | | | | | | | | | | | |
| Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | | | | | | | | | | | | |
| Testing Laboratory
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright
Testing Evaluation Lab., Inc. V.K. Wright | Signed by
V.K. Wright
V.K. Wright
V.K. Wright | | | | | | | | | | | |
| | Signed & Sealed by
Lyndon F. Schmidt, P.E. | | | | | | | | | | | |
| | Signed & Sealed by
Lyndon F. Schmidt, P.E. | | | | | | | | | | | |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409

This item has been digitally signed and sealed by L. F. Schmidt on 2-5-25.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA