

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513642A

Manufacturer: Viwinco, Inc.
Morgantown Business Park
P. O. Box 499
Morgantown PA 19543-0499

Product Line: S-Series Stacked Fixed/Casement/Fixed Combo Ass'y - 36" x 120"

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02843 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI-E7945.01-109-47 signed by Timothy J. McGill.
Architectural Testing, Inc., York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.13 psf
Water penetration resistance 7.52psf
3. Anchor calculations, report number 513642-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 50.0 psf
- Unit size: 36" x 120"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02843, Revision A.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

