

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 513642B**

**Manufacturer:** Viwinco, Inc.  
Morgantown Business Park  
P. O. Box 499  
Morgantown PA 19543-0499

**Product Line:** S-Series Stacked Fixed/Casement/Fixed Combo Ass'y - 36" x 120"

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02843 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI-E7945.01-109-47 signed by Timothy J. McGill.  
Architectural Testing, Inc., York, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 50.13$ psf  
Water penetration resistance 7.52psf
3. Anchor calculations, report number 513642-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure:  $\pm 50.0$ psf
- Unit size: 36" x 120"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02843, Revision A.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

