

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: DIXIE SUPPLY 26 Ga. STEEL CORRUGATED ROOF PANEL,
21 1/2" WIDE x 1/2" CORRUGATED OVER 1/2" PLYWOOD with
1x4 WOOD BATTENS (or) OVER 7/16" OSB with 1x4 WOOD BATTENS

MANUFACTURER: DIXIE BUILDING SUPPLY, Inc.
4906 HIGHWAY 45
EIGHT MILE, AL 36613

To all concerned,

The Dixie Corrugated Roof Panel, manufactured by Dixie Building Supply, is a non-structural 21 1/2" wide x 1/2" Corrugated 26 Ga. steel roof panel (60 ksi min) that meets the requirements of Section 1507.4 of the 8th Edition (2023) Florida Building Code. The panel has been tested per UL 580 and UL 1897 by Force Engineering & Testing and by Intertek B&C, with results shown in test reports 234-001 6T-09D, E, F, & G, Q3009.11-450-18, Q3009.12-450-18, and R1523.05-450-34-R1. It has also been tested per ASTM G155 by PRI Construction Materials Technologies, with results shown in test report 945T0004.

Technical Documentation:

1. Drawing "DCORSWB" dated 3/5/24 (Rev. 1), signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Force Engineering & Testing, signed and sealed by Terrance Wolfe PE, and by Intertek B&C. signed and sealed by Tanya Dolby, PE.
3. Test Reports listed above by PRI, signed and sealed by Zachary Priest, PE.
4. Supplemental Calculations to support DCORSWB, signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapter 15 specifically, for use outside of the High Velocity Hurricane Zone.

Limitations: This panel is approved for use outside of the HVHZ.

Overall Limitations:

Min. Slope:

1/2":12"

Note:

Slopes less than 3":12" require lap sealant per FBC 1507.4

Max Panel Width:

21 1/2" (Nominal)

Min Rib Height:

1/2"

Min Fastener:

#9 x 1 1/2" HWH Fastener with
Weather-seal Washer

Max. Fastener Spacing:

Along Panel:

See Chart Below

Across Panel:

See Chart Below

Max. Design Pressure:

See Chart Below

Substrate:	Fastener Pattern:	Fastener Spacing (Along Panel)	Max. Design Pressure
1x4 Wood Battens (#2 SYP min) over 1/2" Plywood	Pattern #1 (10 3/4" O.C.)	24" O.C.	-93.5 psf
	Pattern #2 (5 3/8" O.C.)	24" O.C.	-131 psf
1x4 Wood Battens (#2 SYP, min) over 7/16" OSB	Pattern #2 (5 3/8" O.C.)	12" O.C.	-191 psf
		15" O.C.	-163.9 psf
		18" O.C.	-145.9 psf
		21" O.C.	-133.1 psf
		24" O.C.	-123.5 psf
		27" O.C.	-116 psf
		30" O.C.	-110 psf
		33" O.C.	-105.1 psf
		36" O.C.	-101 psf

Underlayment: Minimum ASTM D 226 Type II, installed and anchored per FBC Section 1507.1.1.1 (2) or (3) (min).
(or)

Any underlayment with a valid FLPA or Miami-Dade NOA

Fire Barrier: Where required by code, install an approved fire barrier. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. (See note #2 below)

Minimum Substrate: 1/2" (15/32" min) 4-ply CDX Plywood, nailed to 2x rafters spaced 24" max. O.C. with 8d ring-shank nails spaced 6" O.C. with 1x4 Wood Battens (#2 Southern Yellow Pine, min), fastened to the plywood deck with #8x2 1/2" Deck Screws spaced 12" max O.C. (Fastener Pattern #1) or 6" max O.C. (Fastener Pattern #2)

(or)

7/16" OSB nailed to 2x rafters spaced 24" max o.c. with 8d ring-shank nails spaced 4" O.C. with 1x4 Wood Battens (SYP min) fastened to the rafters with (2) #8 x 3" Torx Screws and nailed to OSB with 8d ring-shank nails, staggered at 6" O.C.

Other Limitations:

1. Roof slope must meet requirements of FBC Section 1507.4.2.
2. Fire classification is not a part of this evaluation. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
3. Design of substrate is by others and is not a part of this evaluation.
4. All panel system perimeters, penetrations, and transitions to be flashed and sealed per the manufacturer's installation instructions and RAS 133.

Re-Roofing:

The Dixie Supply 26 Ga. Steel Corrugated Roof Panel may be installed over a single layer of existing asphalt shingles, provided the existing roof meets the requirements of Section 1511 of the Florida Building Code.

If you have any questions or need more information concerning this approval, please contact me.

Thank you,


Scott Wolters
FL PE# 62354
MAR 06 2024

