

L. Roberto Lomas P.E.

208 7th Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513644C

Manufacturer: Viwinco, Inc.
Morgantown Business Park
P.O. Box 499
Morgantown, PA 19543

Product Line: Oceanview Awing - Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02845 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: ATI-B9909.01-109-47 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing Inc., York, PA
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 3
Cyclic Load Test, ± 50.0 psf design pressure
3. Report No.: B7859.01-109-47 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing Inc., York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 70.18 psf
Water penetration resistance 12.11psf
4. Anchor calculations, report number 513644-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 50.0 psf
- Unit size: 60" x 36"
- Units must be glazed per ASTM E1300 see installation instructions for glass details.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02845, Revision B.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

