

WALTER A. TILLIT, JR., P.E.

tilteco@aol.com
FL P.E. License No. 44167
FL C.A. License No. 0006719

PRODUCT EVALUATION REPORT

REPORT NO.: 24-0207.01

DATE: February 7, 2024

PRODUCT CATEGORY: Structural Components

PRODUCT SUB-CATEGORY: Products introduced as a result of new Technology

PRODUCT NAME: MODELS PTG-42MD (PTAC) & VTG-30MD (VTAC) ALUMINUM BLADE LOUVER SYSTEM (L.M.I)

SUBMITTED BY: United Enertech Holdings LLC.
3005 South Hickory Street
Chattanooga, TN 37407

1. PURPOSE OF EVALUATION:

This is a Product Evaluation Report issued by **Walter A. Tillit, Jr., P.E.** (System ID # 1906) to **United Enertech Holdings LLC**, based on **Rule Chapter No. 61G20-3, Method 1D** of the **Florida Department of Business and Professional Regulation**.


This product is being issued an Evaluation Report as described herein, and has been verified for compliance in accordance with the 2023 Eighth Edition of the Florida Building Code, and to verify that the product is for the purpose intended at least equivalent to that required by the Code.

This Product Evaluation Report shall be subject to review and revision in case of a Building Code Change that may affect its limitations and conditions

2. EVIDENCE SUBMITTED:

2.1. PRODUCT EVALUATION DOCUMENT (P.E.D.):

Drawing No.24-015, titled "**MODELS PTG-42MD (PTAC) & VTG-30MD (VTAC)**"



ALUMINUM BLADE LOUVER SYSTEM (L.M.I),” sheets 1 thru 12, prepared by Tilteco, Inc.; signed and sealed by Walter A. Tillit, Jr., P.E.; **dated 2/7/2024**
This drawing is an integral part of this Evaluation Report.

2.2. TEST REPORTS:

Large missile impact and cyclic loadings under Protocols TAS 201 and 203, per sections 1626 and 1609.1.2 of the Florida Building Code, and AMCA 540.

Uniform Static loads in accordance with Protocol TAS 202.

Test Reports prepared by American Testing Lab of South Florida, Report 0202.01-23 dated August 4/2024 signed and sealed by Mr. Stephen Warter, P.E.

2.3. STRUCTURAL ENGINEERING CALCULATIONS:

On Product for maximum span vs. design wind load, as well as maximum anchor spacing vs. design wind load based on rational and comparative analysis, and in accordance with sections 1616 and 1604 of the Florida Building Code. Calculations prepared by Tilteco, Inc., dated 10/19/2023, signed and sealed by Walter A. Tillit, Jr., P.E.

3. MISSILE IMPACT RESISTANCE:


Large missile impact under sections 1626 and 1609.1.2 of the Florida Building Code, as per Protocol TAS 201, and AMCA 540, per section 1609.1.2.1. of the Florida Building Code.

4. WIND LOADS RESISTANCE:

Product has been verified to sustain wind pressures. Maximum Span shall be as indicated on Product Evaluation Document (P.E.D.), Drawing No. **24-015**. Maximum Anchor Spacing shall be as indicated on various cross sections of Product Evaluation Document (P.E.D.), drawing No. **24-015**.

5. INSTALLATION:

Shall be performed strictly in accordance with details indicated on sheets 3 thru 12 of Product Evaluation Document (P.E.D.), drawing No. **24-015**.



6. MATERIAL CHARACTERISTICS AND SPECIFICATIONS:

Shall be strictly in accordance with General Notes and Components indicated on sheets 1 and 2 of 6 of Product Evaluation Document (P.E.D.), drawing No. **24-015**. Anchor specifications shall be as indicated on sheet 2 of Product Evaluation Document (P.E.D.), drawing No. **24-015**

7. LIMITATIONS AND CONDITIONS OF USE:

7.1. Shall be strictly in compliance with General Notes No. 1, 6, 9, 10 indicated on sheet 1, of Product Evaluation Document (P.E.D.), Drawing No **24-015** prepared by Tilteco, Inc. and signed and sealed by Walter A. Tillit, Jr., P.E.

7.2. Product **may be** installed within HIGH VELOCITY HURRICANE ZONES as defined on section 202 of the Florida Building Code and out of it.

7.3. Product **shall only be** installed into 0.090" thick, minimum 6063-T5 aluminum substrate as per note 5, sheet 1 of 6 of Drawing # **24-015**.

Product Evaluation Report prepared by Walter A. Tillit, Jr., P.E. (Florida License No. 44167), President of Tilteco, Inc. (Florida CA-0006719).

WAT\ma

D:\TILTECO ADMON RECORDS\ P. E. REPORT.24 \ UNITED ENERTECH HOLDINGS LLC. \ MODEL **PTG-42MD**
(PTAC) & VTG-30MD (VTAC) **ALUMINUM BLADE LOUVER SYSTEM (L.M.I)** \ DRWG # 24-015 \ REPORT # 24-207.01

