

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION GLASS, INC.
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "HOTEL 450"
ALUMINUM WINDOW/ IMPACT PTAC LOUVER SYSTEM - LMI
LARGE & SMALL MISSILE IMPACT
TEST REPORT # ATLSF 1118.01-21
MAX. UNIT SIZE: 72" X 96"
DESIGN PRESSURE: (MAX.) = -65/+50 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202/TAS203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REPORT DATE	ENGINEER
TAS202-94	AIR INFILTRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	7/24/23 2/18/23 2/15/23	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94	WATER PENETRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	7/24/23 12/15/23 4/11/22 12/18/2023	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	7/24/23 12/11/23 12/18/23 12/20/23 3/8/22 4/11/22 12/15/23	STEPHEN WARTER, P.E. PE #: 54395

SUPPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

TAS 201-94 & TAS 203-94	LARGE MISSILE IMPACT & CYCLIC	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0908.01-16	7/26/23 2/1/24 4/13/23 4/14/23 11/27/23 12/20/23 4/12/22 12/20/23	STEPHEN WARTER, P.E. PE #: 54395
----------------------------	-------------------------------------	----------------------------------	------------------	--	-------------------------------------

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316
STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204



Digitally signed by Christopher Stanton
Date: 2024.04.29 10:29:18 -04'00'



