PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION GLASS, INC.
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "HOTEL 450"
ALUMINUM WINDOW/ IMPACT PTAC LOUVER SYSTEM
NON-IMPACT

TEST REPORT # ATLSF 1117.01-21

MAX. UNIT SIZE: 72" X 96"
DESIGN PRESSURE: (MAX.) = -75/+75 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202/TAS203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REPORT DATE	ENGINEER
TAS202-94 ASTM E283-04 (2012)	AIR INFILTRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1117.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94 ASTM E330-14 (2021) ASTM E547-00	WATER PENETRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94 ASTM E331-00 (2016)	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 202 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431

CHRISTOPHER STANTON
LICENSED
No 69316
STATE OF
FLORIDA
PROFESSIONAL ENGINEER
This item has been digitally signed and sealed by Christopher Stanton, PE on 2/28/2022 using a SHA authentication code.
Printed Copies of this document are not considered signed & sealed and the SHA authentication code must be verified on any electronic copies.
Digitally signed by Christopher Stanton
Date: 2024.06.07 14:05:26 -04'00'