

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION GLASS, INC.
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "HOTEL 450"
ALUMINUM WINDOW/ IMPACT PTAC LOUVER SYSTEM
NON-IMPACT

TEST REPORT # ATLSF 1117.01-21

MAX. UNIT SIZE: 72" X 96"
DESIGN PRESSURE: (MAX.) = -75/+75 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202/TAS203)

<u>TEST</u>	<u>DESCRIPTION</u>	<u>TEST LOCATION</u>	<u>TEST REPORT #</u>	<u>REPORT DATE</u>	<u>ENGINEER</u>
TAS202-94 ASTM E283-04 (2012)	AIR INFILTRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1117.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94 ASTM E330-14 (2021) ASTM E547-00	WATER PENETRATION	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395
TAS202-94 ASTM E331-00 (2016)	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 1118.01-21	5/24/22	STEPHEN WARTER, P.E. PE #: 54395

UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2023/ 2026 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 202 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2026.10.15
09:07:52 -04'00'

