

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515318

Manufacturer: The Muhler Company, Inc.
630 Skylark Drive
Charleston, SC 29407

Product Line: Muhler Door, Opaque, Outswing, Non-Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04009, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NTS 223-0113 signed and sealed by J. Scott Douglas P.E.
Moisture Intrusion Solutions, Daytona Beach, FL
ASTM E330
Design pressure: ± 60.0 psf
Water pressure: 6psf
3. Anchor calculations, report number 515318-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: $+40.0/-60.0$ psf where water penetration resistance is required
 ± 60.0 psf where water penetration resistance is not required
- Unit size: $37 \frac{1}{2}'' \times 97 \frac{3}{16}''$
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Panel made out of 0.098'' fiberglass skin with foam core.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04009.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

