

Evaluation Report FPA-250-HPW
May 16, 2024

Product Description: DECCO S.A. 250 Hung Picture Window, RP250/NC250

Manufacturer: DECCO S.A., Warsaw, Poland

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (2) Method 2.B. This product complies with the requirements of the 8th Edition (2023) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing FPA-250-HPW, signed and sealed by Lucas A. Turner, P.E
- 3) Florida Building Code Section 1709.5.2
- 4) Test Report 12437.01-106-11, from Molimo, York, PA, with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-17/22
- 5) Supplemental Calculations to support FPA-250-HPW, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-250-HPW.

Limitations of Use: This product:

- May be used in up to sizes and in configurations as shown in FPA-250-HPW
- Achieves Design Pressure Rating of +/-50 psf (ASD)
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires rigid PVC framing as indicated in FPA-250-HPW

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in DECCO S.A. or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2024.05.16
15:23:58 -05'00'

5/16/2024
Lucas A. Turner, P.E.
FL PE #58201