BUILDING DROPS
1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

Drutex S.A.
MB-79N SI Tilt & Turn Window
(Non-HVHZ)(Non-Impact)

for

Florida Product Approval

FL# FL46728

Report No. 10894

Current Florida Building Code

Method:	**1 – D (Engineering Evaluation)**
Category:	**Windows**
Sub – Category:	**Dual Action**
Product:	**MB-79N SI Tilt & Turn Window**
Materials:	**Aluminum 6063-T5**
Product Dimensions:	**See Installation Instructions, DRU036**

Prepared for:
Drutex S.A.
Leszka Gierszewskiego 1, 77-100
Bytow, Poland

Prepared by:
Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 7/9/2026

Contents:

Evaluation Report Pages 1 – 3

Digitally signed by Hermes F. Norero, P.E.
Reason: I am approving this document
Date: 2026.08.07 11:25:37 -04'00'

HERMES F. NORERO LICENSE No. 73778 STATE OF FLORIDA PROFESSIONAL ENGINEER

Hermes F. Norero, P.E.
Florida P.E. No. 73778

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Manufacturer:	**Drutex S.A.**
Product Category:	Windows
Product Sub-Category:	Dual Action
Compliance Method:	State Product Approval Method (1)(d)
Product Name:	**MB-79N SI Tilt & Turn Window (Non-HVHZ) (Non-Impact)**

Scope:

This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Drutex S.A.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **DRU036**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering.
4. Site conditions that deviate from the details of installation instructions **DRU036** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **DRU036** for size and design pressure limitations.

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Quality Assurance: The manufacturer has demonstrated compliance of manufacture of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Keystone Certifications, Inc.** (FBC Organization # QUA1824).

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-17

Referenced Data:

1. Product Testing Performed by **Blackwater Testing Lab**
   (FBC Organization # TST14034)
   Report: BW-DRU-23-047-002 Dated: 11/20/2023

2. Quality Assurance
   Keystone Certification, Inc.
   (FBC Organization #QUA1824)

Installation:

Refer to Installation Instructions (**DRU036**) for anchor types, spacing, and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**DRU036**) for design pressure configurations.

954.399.8478 954.744.4738
BUILDINGDROPS.COM CONTACT@BUILDINGDROPS.COM