



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

Detailed Product Description:**Manufacturer:** VIWINCO, INC.**Manufacturer Address:** 851 HEMLOCK ROAD, MORGANTOWN, PA 19543**Model Name:** OCEANVIEW VINYL HORIZONTAL SLIDING WINDOW**Maximum Load:** +50.1 PSF, -50.1 PSF (Large Missile Impact)**Installation Drawings #** 24-09F**FL 46732****Date:** 4/13/2026

This product does <u>not</u> comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.				
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.				
Comparative analysis used <u> X </u> Yes <u> </u> No				
Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA 101/I.S.2/A440/NAFS)				
Test	Description	Test Location	Test Report Date	Test Report #
ASTM E283	Air Infiltration Leakage	Architectural Testing	5/5/2010	98662.01-109-47
			6/26/2013	C7471.01-109-47
		Molimo	6/18/2025	30487.03-106-12
			2/12/2026	32485.02-106-12
ASTM E331 OR ASTM E547	Water Penetration	Architectural Testing	6/26/2013	C7471.01-109-47
			6/18/2025	30487.03-106-12
		Molimo	2/12/2026	32485.02-106-12
			ASTM E330	Uniform Static Air Press.
6/26/2013	C7471.01-109-47			
Molimo	6/18/2025	30487.03-106-12		
	2/12/2026	32485.02-106-12		
ASTM F588	Forced Entry Test	Architectural Testing	6/26/2013	C7471.01-109-47
			6/18/2025	30487.03-106-12
		Molimo	2/12/2026	32485.02-106-12
			Supplemental Tests	
Test	Description	Test Location	Test Report Date	Test Report #
ASTM E1886/1996	Large Missile Impact & Cyclic	Architectural Testing	5/3/2010	99624.01-109-47
			6/26/2013	C7471.02-109-47
		Intertek	1/30/2024	Q5927.02-109-47
			Molimo	6/18/2025
2/12/2026	32485.02-106-12			
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.				
Evaluation Report Engineer:				
Jalal Farooq Al-Farooq Corporation				
PE # 81223 EB # 3538			Sealed: 4/13/2026	