



ENGINEERING

Rice Engineering, Inc.
105 School Creek Trail | Luxemburg, WI 54217
(P) 920.617.1042 | (F) 920.617.1048

Manufacturer:

Winco Window Co.
6200 Maple Ave.
St. Louis, MO 63130

Product Line:

3250 Project-Out-Awning – (Non-Impact)

Product Description:

Architectural Aluminum Window. The frame is made from 6063-T6 Aluminum. Insulated Glass, outboard to inboard, consisting of (5mm AN) - (5/8" Air) - (5mm AN)

Compliance:

The above product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.006. The product Herein complies with the Florida Building Code 8th Edition (2023).

Documentation:

1. Report No: 23026I-PO17
Mid America Testing Laboratory, INC
2. AAMA CPD# 21411
3. Anchor Calculations prepared, signed, and sealed by Wayne Helmila, PE
4. Drawings titled 3250 PO Non-Impact prepared, signed, and sealed by Wayne Helmila, PE

Codes & Limitations:

1. ASTM E330-14 (2021) +\ - 80 psf
2. ASTM E1300-16
3. AAMA/WDMA/CSA 101/I.S.2/A440-17 AW-PG80-1524x914 (60x36)-AP
4. Max. window size 60" x 36"
5. Max. design pressure +\ - 80 psf
6. The product is not approved for large missile impact protection.
7. The product is not approved for use in HVHZ zones.
8. Units must be installed in accordance with manufacturer instructions.

Certificate of Independence:

I certify that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Additionally, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Wayne K Helmila

Digitally signed by Wayne K Helmila
DN: CN=Wayne K Helmila,
dnQualifier=A01410C0000018CDB8F4AFB001A652B,
O=Wisconsin, C=US
Date: 2024.06.04 15:00:33-05'00'


Engineering Evaluation Report



ENGINEERING

105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092



06/04/2024
COA: 9090