



NEMO|etc.

Certificate of Authorization #32455
353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

TEST

CONSULT

P.E. EVALUATION REPORT (PEER)

Henry® A Carlisle Company

336 Cold Stream Rd.
Kimberton, PA 19442
(610) 933-8888

PEER-HNRY-003.A.R1

FL46826-R1 (NON-HVHZ)

Date of Issuance: 06/20/2024

Revision 1: 10/08/2026

SCOPE:

This P.E. Evaluation Report (henceforth 'PEER') is issued under **F.A.C. Rule 61G20-3** and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for compliance with the **9th Edition (2026) Florida Building Code** [sections noted herein](#).

DESCRIPTION: Henry EPDM Single Ply Roof Systems (NON-HVHZ)

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.

CONTINUED COMPLIANCE: This PEER is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our PEERs by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO ETC, LLC requires a complete review of its PEER relative to updated Code requirements with each Code Cycle. Reference is made to the NEMO|etc. [Directory of P.E. Evaluations](#) to ascertain the status and/or current version of this PEER. If the PEER is not listed at the Nemo Directory, then it is no longer valid.

ADVERTISEMENT: "NEMO P.E. Evaluated" may be displayed in advertising literature. If any portion of the PEER is displayed, then it shall be in its entirety.

INSPECTION: Upon request, a copy of this entire PEER shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.


This PEER consists of pages 1 through 4, plus 7-pages of Appendix.

Prepared by:

Digitally signed by
Robert Nieminen
Date: 2026.10.08
'15:14:41 -04'00

This item has been digitally signed and sealed by
Robert Nieminen, P.E.

Printed copies of this document are not
considered signed and sealed, and the signature
must be verified on any electronic copies.
Robert Nieminen, Florida P.E. 59166, FBC ANE1983
NEMO ETC, LLC, Florida CA #32455



CERTIFICATION OF INDEPENDENCE:

1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the PEERs are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

©2019 NEMO ETC, LLC

ROOFING SYSTEMS EVALUATION:
1. SCOPE:

Product Category: Roofing

Sub-Category: Single Ply Roof Systems

Product Approval Method: Method 1, Option D – Codified Material, Evaluation by Engineer

Compliance Statement: **Henry EPDM Single Ply Roof Systems**, as produced by **Henry Company**, have demonstrated compliance with the following sections of the **9th Edition (2026) Florida Building Code** through testing in accordance with the following Standards. Compliance is subject to the [Installation Requirements](#) and [Limitations of Use](#) set forth herein.

2. STANDARDS:

<u>SECTION</u>	<u>PROPERTY</u>	<u>STANDARD</u>
1504.3.1	Wind resistance	FM 4474
1504.7	Impact resistance	FM 4470, Section 4.6
1507.12.2	Material standard	ASTM D4637

3. REFERENCES:

<u>ENTITY</u>	<u>EXAMINATION</u>	<u>REFERENCE</u>	<u>DATE</u>
NEMO	PEER	PEER-CRL-001.A.R10	09/10/2026
NEMO	Traceability	PCL	05/08/2024
UL, LLC (QUA9625)	Quality Control	Service Confirmation	05/15/2024
UL, LLC (QUA9625)	Quality Control	Florida BCIS	Current

4. PRODUCT DESCRIPTION:

This PEER covers **Henry EPDM Single Ply Roof Systems** installed in accordance with **Henry Company** published installation instructions and the [Limitations of Use](#) herein.

TABLE 1: EVALUATED MEMBRANES						
TYPE	PRODUCT		MATERIAL STANDARD			PLANT(s)
			REFERENCE	TYPE	GRADE	
ROOF COVER	Henry Black EPDM Membrane	45, 60	ASTM D4637	I	N/A	PA, IL

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance. PEERs are not to be construed as representing any attributes not specifically listed, nor are PEERs to be construed as an endorsement of the subject, or a recommendation for its use. There is no warranty by NEMO ETC, LLC or Robert Nieminen, P.E., express or implied, as to any finding or other matter in this PEER, or as to any product covered by the PEER.
- 5.2 This PEER is not for use in FBC High Velocity Hurricane Zone jurisdictions, as defined in FBC Chapter 2 (Broward and Miami-Dade Counties).
- 5.3 This PEER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- 5.4 This PEER does not include evaluation of fire classification. Refer to **FBC 1505** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.
- 5.5 This PEER does not include evaluation of roof edge termination. Refer to **FBC 1504.5** for requirements and limitations regarding edge securement for low-slope roofs.
- 5.6 Refer to **FBC 1511** for requirements and limitations regarding recover installations.
- 5.6.1 For mechanically attached components over existing roof decks, fasteners shall be tested in the existing deck for withdrawal resistance. A qualified design professional shall review the data for comparison to the minimum requirements for the system. Testing shall be in accordance with [ANSI/SPRI FX-1](#) or [Testing Application Standard TAS 105](#).
- 5.6.2 For bonded insulation or membrane over existing substrates in a re-roof (tear off) or recover installation, the existing deck or existing roof surface shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing in accordance with [ANSI/SPRI IA-1](#), [ASTM E907](#), [FM Loss Prevention Data Sheet 1-52](#) or [Testing Application Standard TAS 124](#) shall be conducted on mock-ups of the proposed new roof assembly.
- 5.6.3 For bonded insulation or membrane over existing substrates in a recover installation, the existing roof system shall be capable of resisting project design pressures on its own merit to the satisfaction of the Authority Having Jurisdiction, as documented through field uplift testing in accordance with [ASTM E907](#), [FM Loss Prevention Data Sheet 1-52](#) or [Testing Application Standard TAS 124](#).
- 5.7 Refer to Appendix 1 for system attachment requirements for wind load resistance.
- 5.7.1 “MDP” = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads, and reflects the ultimate passing pressure divided by 2 (the 2 to 1 margin of safety per **FBC 1504.9** has already been applied). Refer to **FBC 1609** for determination of design wind loads.
- 5.7.2 For mechanically attached components or partially-bonded insulation, the maximum design pressure for the selected assembly shall meet or exceed at least the Zone 1 PRIME design pressure determined in accordance with **FBC Chapter 16**. Elevated pressure zones shall employ an attachment density designed by a qualified design professional to resist the elevated pressure criteria. Commonly used methods are [ANSI/SPRI WD1](#), [FM Loss Prevention Data Sheet 1-29](#), [Roofing Application Standard RAS 117](#) or [RAS 137](#). Assemblies marked with an asterisk* carry the limitations set forth in **Section 2.2.10.1 of FM Loss Prevention Data Sheet 1-29** for Zone 2/3 enhancements.
- 5.7.3 For assemblies with all components fully bonded in place, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with **FBC Chapter 16**. No rational analysis is permitted for these systems.

5.8 Corrosion Resistance – Saltwater Environments:

Fasteners and connectors, if applicable, in areas within 3,000 feet of a saltwater coastline shall demonstrate compliance with FBC 1711 to the satisfaction of the Authority Having Jurisdiction.

6. INSTALLATION:

Henry EPDM Single Ply Roof Systems shall be installed in accordance with **Henry Company** published installation instructions, subject to the [Limitations of Use](#) noted herein.

7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the named QA entity for manufacturing facilities covered by **F.A.C. Rule 61G20-3** QA requirements. Refer to [Section 4](#) herein for products and production locations having met codified material standards.

9. QUALITY ASSURANCE ENTITY:

[UL LLC – QUA9625](#); (360) 817-5512; bsai.inspections@ul.com

Products listed in [Rule 61G20-3.001](#), **F.A.C.**, shall be manufactured under a quality assurance program audited by an approved quality assurance entity. Refer to the Product Approval of the component manufacturer for components produced by a Product Manufacturer other than the report holder on [Page 1](#) of this PEER.

- THE 7-PAGES THAT FOLLOW FORM PART OF THIS PEER -

APPENDIX 1: ATTACHMENT REQUIREMENTS FOR WIND UPLIFT RESISTANCE

TABLE	DECK	APPLICATION	TYPE	DESCRIPTION	PAGE
1A	Wood	New, Reroof (Tear-Off), Recover	C-1	Mechanically Attached Insulation, Bonded Roof Cover	5
2A	Steel or Structural Concrete	New, Reroof (Tear-Off), Recover	C-1	Mechanically Attached Insulation, Bonded Roof Cover	6
3A	Existing gypsum	Reroof (Tear-Off), Recover	C-1	Mechanically Attached Insulation, Bonded Roof Cover	7

The following notes apply to the systems outlined herein:

- The roof system evaluation herein pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- Unless otherwise noted, fasteners and stress plates shall be as follows. Fasteners shall be of sufficient length for the following engagements:

FASTENER/PLATE OPTIONS		
DECK TYPE	PARTS	MINIMUM ENGAGEMENT
Wood	Carlisle HP Fastener with Carlisle Insulation Fastening Plate	Minimum ¾-inch plywood penetration or minimum 1-inch wood plank embedment
Steel	Carlisle HP Fastener with Carlisle Insulation Fastening Plate	Minimum ¾-inch steel penetration and engage the top flute of the steel deck
Structural Concrete	Carlisle HD 14-10 Fastener, Carlisle CD-10 or HP Concrete Spike (1/4) with Carlisle Insulation Fastening Plate	Minimum 1-inch embedment. Fastener installed with a pilot hole in accordance with the fastener manufacturer's published installation instructions

- Unless otherwise noted, insulation may be any one layer or combination of FBC Approved (Local or Statewide) board(s) that meet FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover.
- Minimum 200 psi, minimum 2-inch thick FBC Approved lightweight insulating concrete may be substituted for rigid insulation board for System Types B-1, C-1, C-2, D-1 or D-2, whereby fasteners are installed through the lightweight insulating concrete to engage the structural deck. The structural deck shall be of equal or greater type, thickness and strength to the steel and structural concrete deck listings. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction. This is a wind uplift resistance allowance and does not purport to address non-wind-uplift-related issues, such as deck venting or moisture levels within the LWIC and the potential effect on overlying components.
- RESERVED
- RESERVED
- RESERVED
- RESERVED
- For mechanically attached components or partially-bonded insulation, the maximum design pressure for the selected assembly shall meet or exceed at least the Zone 1 PRIME design pressure determined in accordance with FBC Chapter 16. Elevated pressure zones shall employ an attachment density designed by a qualified design professional to resist the elevated pressure criteria. Commonly used methods are [ANSI/SPRI WD1](#), [FM Loss Prevention Data Sheet 1-29](#), [Roofing Application Standard](#) RAS 117 and RAS 137. Assemblies marked with an asterisk* carry the limitations set forth in Section 2.2.10.1 of [FM Loss Prevention Data Sheet 1-29](#) for Zone 2/3 enhancements.
- RESERVED
- For mechanically attached components over existing decks, fasteners shall be tested in the existing deck for withdrawal resistance. A qualified design professional shall review the data for comparison to the minimum requirements for the system. Testing and analysis shall be in accordance with [ANSI/SPRI FX-1](#) or [Testing Application Standard](#) TAS 105.
- RESERVED
- Refer to FBC 1511 for requirements and limitations regarding recover installations. For Structural Concrete Deck or Recover Applications using System Type C-1 the base insulation layer is optional and for System Type C-2, D-1 or D-2, the insulation is optional. Alternatively, an FBC Approved insulation board or coverboard may be used as a separation layer. Board products shall be preliminarily attached prior to roof cover installation ([Note 17](#)). The separator component shall be documented as meeting FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover in Recover applications.

14 RESERVED

15 For bonded membrane applications, unless otherwise noted, refer to the following.

MEMBRANE / ADHESIVE COMBINATIONS			
MEMBRANE	ADHESIVE	METHOD	RATE
Henry Black EPDM	Henry Low-VOC EPDM Bonding Adhesive	Contact (both sides)	0.83 gal/square per surface [(1.66 gal/square (60 ft ² /gal) finish)]

15A Side laps shall be sealed in accordance with Henry requirements:

- Primed with Henry Low-VOC EPDM Primer and adhered with Henry White Seam Tape.

16 **Thermal Barrier and/or Vapor Barrier Options:**

16A For System Types B-1, B-2, C-1, C-2, D-1 or D-2, Carlisle “VapAir Seal 725TR” or “VapAir Seal MD” may be installed atop the roof deck prior to installation of the insulation and roof cover. Refer to [FM Loss Prevention Data Sheet 1-29](#) for design and installation limitations.

17 **Insulation Attachment:**

17A Unless otherwise noted, insulation may be any one layer or combination of FBC Approved (Local or Statewide) board(s) that meet FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover.

17B For System Types B-1, C-1 or C-2, optional one or more layer(s) of FBC Approved board-stock roof insulation may be installed atop the substrate prior to mechanical attachment of the subsequent top layer, with no adverse effect on the MDP performance limitation.

17C **Preliminary Insulation Attachment:**









Unless otherwise noted, use Approved roofing fasteners and plates; minimum two (2) parts per 4x4 ft board, minimum four (4) parts per 4x8 ft board.

For systems where a vapor barrier is installed refer to Section 2.2.10.1.3 of [FM Loss Prevention Data Sheet 1-29](#).


For systems where no vapor barrier is installed, Carlisle InsulFast may be used in place of Carlisle HP Fastener for preliminary attachment purposes over wood and steel deck.

17D Unless otherwise noted, insulation or coverboard attachment patterns for Type B-1, Type B-2, Type C-1 and C-2 systems are as outlined below.

INSULATION ATTACHMENT PATTERNS – 4x4 FT BOARDS

 1 per 4.0 ft² (4 per board)	 1 per 3.2 ft² (5 per board)	 1 per 2.7 ft² (6 per board)	 1 per 2.0 ft² (8 per board)
 1 per 1.8 ft² (9 per board)	 1 per 1.6 ft² (10 per board)	 1 per 1.3 ft² (12 per board)	 1 per 1.0 ft² (16 per board)

INSULATION ATTACHMENT PATTERNS – 4x8 FT BOARDS



18 The following products are interchangeable within the scope of this Evaluation Report:

ACCEPTABLE ALTERNATES				
SUB-CATEGORY	BY	LISTED PRODUCT HEREIN	ALTERNATE	FBC FILE
ROOFING INSULATION	Henry	Henry Polyiso Insulation	Carlisle InsulBase, Carlisle InsulBase NH, Hunter H-Shield, Hunter H-Shield NH	FL5968
	Carlisle SynTec	SecurShield	Carlisle SecurShield NH, Hunter H-Shield CG, Hunter H-Shield CG NH	
	Henry	Henry High Density CGF ISO Coverboard	Carlisle SecurShield HD, Carlisle SecurShield HD NH, Hunter H-Shield HD, Hunter H-Shield HD NH	
	Carlisle SynTec	SecurShield HD Plus	Carlisle SecurShield HD Plus NH, Hunter H-Shield HD90, Hunter H-Shield HD90 NH	
	Carlisle SynTec	SecurShield HD Composite	Hunter H-Shield HD Composite	
	Georgia-Pacific Gypsum, LLC	DensDeck Prime	DensDeck StormX Prime Roof Board	FL1250

19 "MDP" = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads. Refer to FBC 1609 for determination of design wind loads. ([Note 9](#) and [Note 10](#))

TABLE 1A: WOOD DECKS - NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER							
System No.	Deck (Note 1)	Base Insulation Layer (Note 13 , Note 17)	Top Insulation Layer			Roof Cover (Note 15)	MDP (psf)
			Type	Fasteners (Note 2 , Note 11)	Attach		
MEMBRANE APPLIED IN HENRY LOW-VOC EPDM BONDING ADHESIVE:							
W-1	Min. 19/32-inch CDX plywood or wood plank; 2-ft spans	One or more layers, any combination, loose laid	Min. 0.5-inch Henry High Density CGF ISO Coverboard or Carlisle SecurShield HD Plus	Henry Insulation Fasteners with SecurFast Insulation Fastening Plate	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-30.0
W-2	Min. 19/32-inch CDX plywood or wood plank; 2-ft spans	One or more layers, any combination, loose laid	Min. 0.5-inch Henry High Density CGF ISO Coverboard or Carlisle SecurShield HD Plus	Henry Insulation Fasteners with Henry Insulation Fastening Plate	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-37.5
W-3	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
W-4	Min. 19/32-inch plywood or wood plank	(Optional) One or more layers, any combination, loose laid	Min. 2.0-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 4.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
W-5	Min. 19/32-inch plywood or wood plank	One or more layers, any combination, loose laid	Min. 0.25-inch thick DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	Note 2	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
W-6	Min. 23/32-inch plywood	One or more layers, any combination, loose laid	Min 0.5-inch SECUROCK Gypsum-Fiber Roof Board	Note 2	1 per 3.2 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*

TABLE 2A: STEEL OR STRUCTURAL CONCRETE DECKS - NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER

System No.	Deck (Note 1)	Base Insulation Layer (Note 13 , Note 17)	Top Insulation Layer			Roof Cover (Note 15)	MDP (psf)
			Type	Fasteners (Note 2 , Note 11)	Attach		
MEMBRANE APPLIED IN HENRY LOW-VOC EPDM BONDING ADHESIVE:							
SC-1	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch thick, one or more layers, any combination, loose laid	Min. 0.5-inch Henry High Density CGF ISO Coverboard	Steel: Henry Insulation Fasteners with OMG ACCUTRAC Fastening Plate Concrete: Carlisle HD 14-10, CD-10 or HP Concrete Spike (1/4) with OMG ACCUTRAC Insulation Fastening Plate	1 per 4.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-30.0*
SC-2	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch thick, one or more layers, any combination, loose laid	Min. 0.5-inch Henry High Density CGF ISO Coverboard	Note 2	1 per 2.7 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-37.5*
SC-3	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 1-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 1.6 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
SC-4	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 3.2 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
SC-5	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 2.0-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 4.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
SC-6	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch thick, one or more layers, any combination, loose laid	Min. 0.5-inch Carlisle SecurShield HD Plus	Note 2	1 per 4.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
SC-7	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 0.25-inch thick DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	Note 2	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
SC-8	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1-inch Henry Polyiso Insulation or Carlisle SecurShield	Min. 0.5-inch DensDeck Prime	Note 2	1 per 1.6 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-52.5
SC-9	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 2-inch Carlisle SecurShield	Note 2	1 per 2.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-60.0
SC-10	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch Henry Polyiso Insulation or Carlisle SecurShield	Min. 0.5-inch Carlisle SecurShield HD Plus	Note 2	1 per 1.8 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-60.0
SC-11	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 2-inch Henry Polyiso Insulation or Carlisle SecurShield	Note 2	1 per 1.6 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-75.0

TABLE 2A: STEEL OR STRUCTURAL CONCRETE DECKS - NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER

System No.	Deck (Note 1)	Base Insulation Layer (Note 13 , Note 17)	Top Insulation Layer			Roof Cover (Note 15)	MDP (psf)
			Type	Fasteners (Note 2 , Note 11)	Attach		
SC-12	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1-inch Henry Polyiso Insulation or Carlisle SecurShield	Min. 0.5-inch SECUROCK Gypsum-Fiber Roof Board	Note 2	1 per 1.6 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-75.0
SC-13	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 2-inch Carlisle SecurShield or Carlisle SecurShield HD Composite	Note 2	1 per 1.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-112.5
SC-14	Min. 22 ga., type B, Grade 33 steel or min. 2,500 psi structural concrete	Min. 1.5-inch Henry Polyiso Insulation or Carlisle SecurShield	Min. 0.5-inch Carlisle SecurShield HD Plus	Note 2	1 per 1.3 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-112.5
SC-15	Min. 22 ga., type B, Grade 80 steel or min. 2,500 psi structural concrete	(Optional) One or more layers, any combination, loose laid	Min. 2-inch Carlisle SecurShield or Carlisle SecurShield HD Composite	Note 2	1 per 1.0 ft²	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-127.5

TABLE 3A GYPSUM DECKS - REROOF (TEAR-OFF) OR RECOVER
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER

System No.	Deck (Note 1)	Base Insulation Layer (Note 13)	Top Insulation Layer				Roof Cover (Note 15)	MDP (psf)
			Type	Fastener (Note 11)	Attach	Min. Withdrawal (lbf)		
MEMBRANE APPLIED IN HENRY LOW-VOC EPDM BONDING ADHESIVE:								
G-1.	Existing gypsum deck	(Optional) One or more layers, any combination	Min. 1.5-inch Henry Polyiso Insulation, Carlisle SecurShield or Carlisle SecurShield HD Composite	Carlisle Gyptec Fastener with Gyptec Plate-3" or Carlisle Lite Deck Fastener with Lite Deck Plate, min. 2-inch embed.	1 per 3.2 ft²	240	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-37.5*
G-2.	Existing gypsum deck	(Optional) One or more layers, any combination	Min. 1.5-inch Henry Polyiso Insulation, Carlisle SecurShield or Carlisle SecurShield HD Composite	Carlisle Gyptec Fastener with Gyptec Plate-3" or Carlisle Lite Deck Fastener with Lite Deck Plate, min. 2-inch embed.	1 per 2.0 ft²	180	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*
G-3.	Existing gypsum deck	(Optional) One or more layers, any combination	Min. 2-inch Henry Polyiso Insulation, Carlisle SecurShield or Carlisle SecurShield HD Composite	Carlisle Gyptec Fastener with Gyptec Plate-3" or Carlisle Lite Deck Fastener with Lite Deck Plate, min. 2-inch embed.	1 per 4.0 ft²	360	Henry Black EPDM Membrane applied in Henry Low-VOC EPDM Bonding Adhesive	-45.0*