



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 46869

Date: 6/5/2024

Detailed Product Description:

Manufacturer: K2 Systems, LLC

Manufacturer Address: 4665 North Ave. Suite 1 Oceanside CA, 92056

Model Name: Standing Seam Metal Roof PV Mounting System

Maximum Load: +129 PSF, -129 PSF

Installation Drawings # 24-27F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <u> X </u> Yes <u> </u> No					
Tested in accordance with TAS-202, ASTM D1761					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM D1761	Mechanical Fasteners in Wood	International Code Council	03/21/2024	KSLA082423-79	Gary T Hartman, PE
TAS 202	Uniform Static Air Press.	International Code Council	04/10/2024	KSLA110823-14-B	Gary T Hartman, PE
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.					
Evaluation Report Engineer: Jalal Farooq Al-Farooq Corporation			 Sealed: 6/25/2024		