

**PRODUCT EVALUATION REPORT****- Florida Building Code - 8th Edition (2023) -****Per Rule 61G20-3 / Method 1 - D****FL #:** 46870.2**DATE:** 02/03/2025**Product Description**

Manufacturer: AA IMPACT GARAGE DOOR
Address: 2235 W 10th Court, Hialeah, FL 33010
Model Name: Aluminum and Glass Sectional Garage Door 16'-2" (194") Max. Width (L.M.I.)
Maximum Load: +46.0 PSF / -55.0 PSF (Large Missile Impact)
Drawing No.: JA-1104.1-25, signed and sealed by Javad Ahmad, P.E. - FL License No. 70592


This product COMPLIES with the 2023 Florida Building Code - 8th Edition (2023 FBC) for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative Analysis used: ☒ YES ☐ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
TAS 202-94	Uniform Static Test	IFET, Inc.	05/01/2024	TR-IFET-23-0018.01	Arshad Viqar, P.E.
Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
TAS 201-94	Impact Test (Large Missile Impact)	IFET, Inc.	05/01/2024	TR-IFET-23-0018.01	Arshad Viqar, P.E.
TAS 203-94	Cyclic Wind Pressure Load	IFET, Inc.	05/01/2024	TR-IFET-23-0018.01	Arshad Viqar, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code - 8th Edition (2023 FBC).



Sealed:
02/03/2025

Evaluation Report Engineer:

Javad Ahmad, PE
FL P.E.# 70592
EB C.A.N. # 34254
JAVAD AHMAD PE, Inc.