

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515387

Manufacturer: Acadian Windows and Siding, LLC
119 Alpha Drive
Destrehan, LA 70047

Product Line: Acadian Windows Impact Series Fixed 64" x 84"

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04058, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: ESP 2088W-2R/3R/010455P-2R/3R signed and sealed by Ramesh Patel, P.E.
Element Materials Technology, Wausau, WI
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±80.0psf
Water resistance: 12.0psf
ASTM E1886 / E1996
Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Load Test ±50.0psf design pressure.
3. Anchor calculations, report number 515387-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ±50.0 psf
- Unit size: 64" x 84"
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04058.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

