

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515391

Manufacturer: Acadian Windows and Siding, LLC
119 Alpha Drive
Destrehan, LA 70047

Product Line: Acadian Compass Series Single Hung Window Non-Impact 44" x 78"

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04062, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: ATI-L6907.02-501-47 signed by Stephen D. Shank
Intertek, Springdale, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: +60.15/-55.14psf
Water penetration: 7.52psf
3. Anchor calculations, report number 515391-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: 44" x 78"
- Units must be glazed per ASTM E 1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-04062.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

