

August 20, 2025

Client

JDC Aluminum Tampa, Inc.
4166 Rice Road
Plant City, FL 33566


Project: 250064501

Florida Product Approval

Product Category: Panel Walls

Subcategory: Storefront

Series/Model: SF300 Aluminum Storefront System



This item has been electronically signed and sealed by Marcia Harris, PE on 08/25/2025 using a **SHA** authentication code.

Printed copies of this document are not considered signed and sealed and the **SHA** authentication code must be verified on any electronic copies.

Submitted Technical Documentation:

1. Test Report 2573T0008 dated 03/06/2025 from PRI Construction Materials Technologies, LLC located in Tampa, FL.
TAS 202
AAMA 501-15
AAMA E283-12: Air Infiltration (6.24 psf)
AAMA E331-09: Water Infiltration (15 psf)
AAMA E330-14: Design Pressure (+/- 45 psf)
2. Quality Assurance: Keystone Certifications, Inc..

Certification Statement:

According to the information provided in the above mentioned test report, the SF300T Aluminum Storefront System was tested in accordance with the above referenced standards. Based on the test report and with accepted engineering guidelines to determine the structural capabilities of the system, we certify that the SF300T Storefront system fulfills the requirements of the 2023 Florida Building Code Chapter 24.

Compliance:

The above listed products have been shown to demonstrate compliance with the 2020 Florida Building Code and with the Florida Department of Business and Professional Regulation for Statewide Product Approval as per Rule 61G20-3.

Certificate of Independence:

In accordance with Rule 61G20-3, I do not have, nor do I ever intend to acquire, any financial interest in any manufacturing company associated with this evaluation report. I also do not have any financial interest in the manufacturing company or any company associated with the manufacturing company.