

PRODUCT APPROVAL EVALUATION REPORT
RULE CHAPTER #61G20-3

MANUFACTURER
CHAMPION PTAC, LLC
4720 NW 15TH AVE. UNIT 4A
FORT LAUDERDALE, FL

PRODUCT
SERIES "VTAC"
HURRICANE IMPACT LOUVER SYSTEM
LARGE & SMALL MISSILE IMPACT

TEST REPORT # ATLSF 0222.01-24

MAX. UNIT SIZE: 35-1/2" X 97-1/2"
DESIGN PRESSURE: (MAX.) = -75/+55 PSF

NOTE: THIS PRODUCT COMPLIES WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) TESTING REQUIREMENTS

MANITORY TESTS (TESTED IN ACCORDENCE WITH TAS 201/ TAS202/TAS203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT #	REPORT DATE	ENGINEER
TAS202-94 ASTM E330-14	UNIFORM STATIC AIR PRESSURE	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0222.01-24	3/20/2024	STEPHEN WARTER, P.E. PE #: 54395

SUPLIMENTAL TESTS (TESTED IN ACCORDANCE WITH TAS 201 & TAS 203)

TAS 201-94 & TAS 203-94 ASTM E 1886-13a ASTM E1996-20	LARGE MISSILE IMPACT & CYCLIC	AMERICAN TEST LAB OF SOUTH FL	ATLSF 0222.01-24	3/20/2024	STEPHEN WARTER, P.E. PE #: 54395
--	-------------------------------------	----------------------------------	------------------	-----------	-------------------------------------


UNDER THE LIMITATIONS OF THE ATTACHED INSTALLATION DRAWINGS, TO THE BEST OF MY KNOWLEDGE, THE ABOVE GLAZING SYSTEM PRODUCT CONFORMS TO THE REQUIREMENTS OF THE 2020/ 2023 FLORIDA BUILDING CODE

PLEASE NOTE: TAS 201, 202 & 203 IS EQUIVELANT TO AAMA 501.

EVALUATION REPORT ENGINEER

Christopher Stanton, P.E.
Fla. P.E. #69316

STANTON ENGINEERING INC.
CERT. OF AUTHORIZATION #32093
2701 BOCA RATON BLVD. SUITE #204
BOCA RATON, FL 33431



Digitally signed by
Christopher Stanton
Date: 2025.12.29
16:51:19 -05'00'

